



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:IND/WB/FES/20192020/1/74114

Date: 20-12-2022

From:
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: DELTA PV PRIVATE LIMITED
PLOT NO.- A1-3, BLOCK - GP, SECTOR - V, SALT LAKE, KOLKATA - 700091

Sub: Revised Fire Safety Recommendation in respect of B1+B2+G+4 nos. Podium+ XVIII storied under group Business Building at premises: Salt Lake Electronics Complex, Plot No.: A1-3, Block- GP, Sector- V, Salt lake, Kolkata: 700091, PS: Bidhannagar, Dist.: 24 Parganas (N).

This is in reference to your application no. 0125188221100116 dated 26-09-2022 regarding the Revised Fire Safety Recommendation in respect of B1+B2+G+4 nos. Podium+ XVIII storied under group Business Building at premises: Salt Lake Electronics Complex, Plot No.: A1-3, Block- GP, Sector- V, Salt lake, Kolkata: 700091, PS: Bidhannagar, Dist.: 24 Parganas (N).

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this office is issuing **Revised Fire Safety Recommendation** in favor of the aforesaid building subject to the compliance of the following fire safety measure.

Recommendation:

This is in reference to the Application vide AIN: 0125188221100116 regarding Revised Fire Safety Recommendation in respect of B1+B2+G+4 nos. Podium+ XVIII storied under group Business Building at premises: Salt Lake Electronics Complex, Plot No.: A1-3, Block- GP, Sector- V, Salt lake, Kolkata: 700091, PS: Bidhannagar, Dist.: 24 Parganas (N). One set of plan drawing comprising its Master plan, Site and key plan, Section and elevation, floor plan only of 4 nos. Podium car parking, 17th & 18th floor and roof plan. Remaining floors shall be remain unchanged as per the earlier approval dated 17.02.2020.

However, the earlier FSR which was issued from this Office vide Memo No. IND/WB/FES/20192020/77114 dated 14.02.20 will remain same and strictly to be followed with inclusion of the following additional points:

- 1.Pressurised Fire fighting shaft shall have to be provided with a pressurisation level 25 Pa to 30 Pa at normal situation and 50 Pa at fire situation.
- 2.Water requirement for Fire shall be provided as per the approved plan drawing.
- 3.Emergency smoke venting system integrated with CO sensors shall be installed at both basements to achieve minimum

12 air changes per hour.

Signature Not Verified
Digitally signed by ABHIJIT
PANDEY
Date: 2022.12.20 13:52:18 IST

Director
West Bengal Fire & Emergency Services

Memo No.: IND/WB/FES/20192020/1/1114