



Government Of West Bengal  
Office Of The Deputy Director  
West Bengal Fire & Emergency Services  
Station Feeder Road, P.O & P.S Siliguri,  
District: Darjeeling, Pin - 734005

Memo no.:FSR/0125186227900072

Date: 03-06-2022

From:  
Deputy Director  
North Zone, HQ Wing,  
West Bengal Fire & Emergency Services

To: SRI. DIL BAHADUR CHHETRI  
PARGANA- BAIKUNTHAPUR, MOUZA- DABGRAM, PLOT NO- 630(R.S.), 250 (L.R.), KHATIAN NO- 701/7 (R.S.),  
158(L.R.), SHASTRI NAGAR, SEVOKE ROAD, WARD NO- 41, P.S.- BHAKTINAGAR, DIST- JALPAIGURI

Sub: Issuance of Fire Safety Recommendation AIN No-0125186227900072 under G+4 Residential Building named SRI DIL BAHADUR CHHETRI, PARGANA-BAIKUNTHAPUR, MOUZA-DABGRAM, PLOT NO-630(RS)250(LR, KHATIAN NO-701/7(RS), 158(LR), SHASTRI NAGAR, SEVOKE ROAD, WARD NO-41, PS-BHAKTINAGAR, DIST-JALPAIGURI.

This is in reference to your application no. 0125186227900072 dated 14-03-2022 regarding the Issuance of Fire Safety Recommendation AIN No-0125186227900072 under G+4 Residential Building named SRI DIL BAHADUR CHHETRI, PARGANA-BAIKUNTHAPUR, MOUZA-DABGRAM, PLOT NO-630(RS)250(LR, KHATIAN NO-701/7(RS), 158(LR), SHASTRI NAGAR, SEVOKE ROAD, WARD NO-41, PS-BHAKTINAGAR, DIST-JALPAIGURI.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this is issuing Fire Safety Recommendation in favor of the aforesaid building subject to the compliance of the following fire safety measure.

**Recommendation:**

With reference to the letter noted above regarding the Fire Safety Recommendations for the Proposed Residential building, different papers were received inter alia the Building Plan. After scrutinizing all the papers and the building plan from fire & life safety point of view, the fire safety recommendation is here by issued as per the direction of the authority subject to the compliance of the same before occupancy.

**Recommendations:-**

- A) Construction Part:-i) The whole construction of the proposed building shall be carried out as per approved plan & conforming all the relevant building rules of local authority.  
ii) The floor area exceeds 750 sq.miter shall be suitably compartmented by separation walls up to ceiling level having at least two hrs. fire resisting capacity.  
iii) The interior finish decoration of the building shall be made of low flame spread materials conforming I.S Specification.  
iv) All construction materials should be of four hrs. Fire resisting type.

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number: 0125186227900072

Page 1

- i) Regular check up of all split type window A/C machine to prevent dust, foreign materials in the air inlet should be maintained to prevent spontaneous combustion.
- ii) In case of central A/C system, the same shall be incorporated with automatic damper with fusible link with a view to shut down the system automatically.
- iii) Regular checking, testing, cleanings the air inlets is must.
- iv) Escape routes like corridors, lift lobbies etc. shall not be used as return air passage.
- v) AHU shall not be used for storage of combustible articles.
- H) Fire Fighting Water:- The building should be provided with 50000 liters capacity of underground stored water with replenishing arrangement @ 1000 liters of water per minutes preferably from two different sources. The height of the reservoir should not be exceed 30 cm from the ground level. Fire water reservoir shall have overflow and connected with domestic water reservoir as well as to avoid stagnancy of water. The water reservoir shall be kept full at all times. The location of the U/G water reservoir should be such so that Fire Service Vehicles may get access to the site of the reservoir with a view to draw the water from the said reservoir.
- I) Small gears:-IS:903-1993:-Hose box, 15 meter length permoline delivery hose, gunmetal short branch of half inch dia @ one set each at or near all the pillar hydrants, landing valves on floors should be installed.
- J) Terrace Tank:-One Terrace Tank of capacity Minimum 10000 liters should be installed in the building along with suitable terrace pump & Wet Riser cum Down comer system.
- K) Hose Reel System:-IS 884-1985, the building should be equipped with Hose reel hose system at each floor as per the IS Code of practice. The internal dia of the said hose reel shall be 19 mm to 32 mm and the discharge capacity not less than 22.5 LPM. While the length of the hose reel not more than 36.5 meters. The distance of such installation should be in such a way that no part of the floor is more than 6 meters distance from a hose nozzle when fully extended.
- L) External Hydrant System:-IS-13039-1991:-The whole area of your building is to be protected by adequate no. of pillar type hydrants system i.e. @ one pillar hydrant per 1000 sq. meters of area or as per the vulnerability of the place.
- M) Pumps for fire fighting Installation.IS-12469-1988.
- i) The pump should be installed and arranged in such a manner so that it will start automatically due to fall in pressure as prefixed in the installation by installing a jockey pump.
- ii) All the pumps shall be so designed as to supply water at the designed pressure and discharge into the water based system which shall be installed in the building.
- iii) One such pump shall always be kept on stand-by preferably be of diesel driven type.
- iv) An independent identical pump for the purpose of sprinkler installation shall be made available. All such arrangement shall be made as per the code of practice.
- N) Detection & Alarm System:-IS 2189-1988. i) Sufficient Nos. of manually operated electrical fire alarm system of break glass type call boxes and fitted with alarm like hooters with public address system, talk back system at different places of the building shall be installed and connecting with audio visual panel board shall be made in control room as per the IS Code of practice. The control Room shall be located in the entrance of the ground floor of the building.
- ii) Automatic fire detection system with the help of Smoke & Heat detectors shall be installed at all places of below and preferably above false ceiling of the building This system shall also be made available in places of rooms where valuables have been kept other requirements shall be made in accordance with the IS code of practice.
- iii) Suppression system shall be made with full flooding system with CO2, FM-200 etc. particularly in computer room, electrical processing and data room and in a room of irreplaceable articles.
- O) First aid fire fighting system:-IS 2190-1992. Sufficient Nos. of Portable fire extinguishers of DCP type, Water type and Sand and water bucket should be provided at different places of the building area and it should be within the reach of all concern as per the I.S Code of practice.
- P) Lighting protection of the building:-This protection for the building shall be provided as given Part:-VIII of building services, Section -2 of Electrical installation.
- Q) General recommendations: - i) Fire notice for fire fighting and evacuation from the building should be provided and shall

be displayed at all places of the building as per clause 5.5 of N.B Code.

- ii) Floor No. and Directional Sign of escape route should be displayed prominently as per clause 5.5 of the N.B Code.(Auto glow type)
- iii) All the staffs and others shall be conversant with the installed fire fighting equipments of the building so that they can operate the same in case of exigency.
- iv) Arrangement shall be made for regular checking, testing and proper maintenance of all fire fighting equipments and keep them in good working condition at all times.
- v) Mock fire drill and evacuation drill should be done periodically with participation of all employees and others and in this regard in each year a Certificate is to be obtained from this end as laid down in the norms.
- vi) A register for the recording of Mock fire drill, Evacuation drill, Testing & Checking of whole Fire fighting installation, Electrical installation should be maintained and shall be liable to produce the same to the authorized Officer of this department on demand.
- vii) Good house keeping should be maintained.

Signature valid

Digitally signed by ABHIJIT  
PANDEY  
Date: 2022.08.03 14:14:12 IST

Deputy Director  
West Bengal Fire & Emergency Services