

GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D, Mirza Ghalib Street, Kolkata-16

Memo No. WBFES/6573/15/15/Hooghly/RB/1450/14(1450/14)

Date- 26-08-15

From : Director-In-Charge, Fire Prevention Wing
West Bengal Fire & Emergency Services
13/D, Mirza Ghalib Street
Kolkata - 16

To : The Authorized Signatory
Deepesh Shoppers Pvt.Ltd.&75 Others
55,Khan Road
J.L.No-9, Ward No-1,
Dist-Hooghly



Sub : Fire Safety recommendation for Proposed construction of 17nos of G +VIII&G+VII storied under group Residential Building at Premises No. 55,Khan Road, Mouza- Mankundu, P.S& Municipality Bhadreswar, J.L.No-9, Ward No-1, Dist-Hooghly

This is in reference to your letter No Nil Dt 24.03.2015 regarding Fire Safety measure for Proposed construction of 17nos of G +VIII&G+VII storied under group Residential Building at Premises No. 55,Khan Road, Mouza- Mankundu, P.S& Municipality Bhadreswar, J.L.No-9, Ward No-1, Dist-Hooghly

The plan drawings submitted by you was scrutinized and marked as found necessary from fire safety point of view. In returning one set of plan with following recommendation, this office instructing that the recommendation issued earlier vide Memo No- WBFES/401/15/ Hooghly/RB/1450/14(1450/14) dt.19.01.15 shall remain same & strictly to be complied. U.G.W.R. shall be of capacity of 400000 Lac Ltrs. only for Fire fighting & it should be constructed as per NBC Part IV&I.S.

Encl:

1. One set of plan.

[Handwritten Signature]
26/8/15

Director-In-Charge
(Fire Prevention Wing)
West Bengal Fire & Emergency Services