



West Bengal State Electricity Distribution Company Limited

(A Govt. of W.B. Enterprise)

Office of the A.E & Station Manager, Midnapore CCC

Power House, Burdge Town, Paschim Medinipur, Pin - 7221101

Phone : 03222275521, E-mail : sm.midnapur@wbsedcl.in

Memo No. MCCC/ 3050

Date: 18/02/22

TO,
SK PARVEZ KIBRIA
SHAH REAL ESTATE
SEPOY BAZAR,
MIDNAPUR
MOB-9933030339.

SUB : NOC for site plan showing area for proposed residential Apartment of Mr. Gobinda Ram Agarwala, S/O Late Dwarka Das Agarwala OF RANGAMATI, P.O. & P.S.-MIDNAPORE, DIST- PASCHIM MEDINIPUR. Developed by-"Shah Real Estate' (ADVFSO443D)-1) SK PARVEZ KIBRIA, S/O:-SK SHAH JAMAL OF SEPOY BAZAR, 2) SURAVI AGARWAL, D/O-SRAVAN KUMAR AGARWAL OF SANGAM GARDEN, TANTIGERIA ON R.S. PLOT NO.-223/361 ,L.R. PLOT NO.-757, MOUZA-RANGAMATI, J.L. NO-150, KHATIAN NO:-876, HOLDING NO:-548/239, WARD NO:-24 P.S.-MIDNAPORE, DIST- PASCHIM MEDINIPUR, UNDER MIDNAPORE MUNICIPALITY UNDER MIDNAPORE CCC.

1. Necessary way leave to be provided by intending consumer.
2. Intending Consumer to apply through Procedure - B for new service connection
3. Intending Consumer to follow IE rule during his construction
4. Intending Consumer to give suitable location in his/her plot for installation of WBSedcl equipments.

Following mandatory clearance to be provided from any OH line from any building as per electricity Act 2003.

1. Vertical Clearance of OH line from heighest point of building is 2.5 mtr for L&MV upto 440 V and 3.7 mtr for HV(11 KV).
2. Horizontal Clearance of OH line from nearest point of building 1.2 mtr for L&MV (upto 440 V) and 1.2 mtr for HV(11 KV).

Intending applicant will apply for construction power service connection for his construction work & surrender existing meters.

Yours faithfully,

A.E & Station Manager
Midnapore Customer Care Center

