

Page No. _____ Date: _____

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES**

Memo No : IND/WB/FES/20202021/87362

DATE: 05/03/2020

From:
Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.

To: Mr. Bidyut Baran Mondal
Durgapur, Paschim Bardhaman,
L.R. Plot no- 2802, J.L No.52, Mouza- Andal,
F.S. Durgapur., P.S Durgapur,
Dist. Paschim Bardhaman-73321.

Sub: Fire Safety Recommendation for a proposed construction of G + 4 storied building under group Residential at the premises no.- Durgapur, Paschim Bardhaman, L.R. Plot no- 2802, J.L No.52, Mouza- Andal, F.S. Durgapur., P.S Durgapur, Dist. Paschim Bardhaman-73321.

This is in reference to your Application No:IND/WB/FES/20202021/87392,dated-05/03/2020, regarding the Fire Safety Measure for a proposed construction of G + 4 storied building under group Residential at the premises no.- Durgapur, Paschim Bardhaman, L.R. Plot no- 2802, J.L No.52, Mouza- Andal, P.S Durgapur, Dist. Paschim Bardhaman-73321..

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this is issuing Fire Safety Recommendation in favour of the afore said building subject to the compliance of the following fire safety measure.

Recommendation:

1.CONSTRUCTION:

1.The whole construction of the proposed building shall be carried out as per approved plan drawings conforming the relevant building rules of local Municipal Body.

2.The floor area exceeds 750m² shall be suitably compartmented by separation walls up to ceiling level having at least two hours Fire resisting capacity.

practice for Fire safety in general building as laid down in I.S. specification 1946 – 1982.

13. The vertical ducts shall be supply sealed at alternative floor level.

14. The major electrical installation shall be adequately protected with CO₂/D.C.P. or Medium Velocity / Projector System.

Alternative Power Supply:

15. Arrangements shall have to be made to supply power with the help of a generator to operate at least the Fire Pump, Pump for deep Tube-well, Fire Alarm System, Fire Lift etc. and also for illuminating the Staircase, corridors etc. and other places of the building in case of normal power failure.

Detection & Alarm System:

16. Manually operated Electrical Fire Alarm system with at least three numbers of break glass type call boxes fitted with Hooters along with public address system, talk back system at each floor connecting with audio-visual panel board shall be made in Control Room. The Control Room shall be located at the entrance of Ground Floor of the building, other requirements of the system shall be made conforming I.S. 2189 – 1988.

17. Hooter will be sounded in such a manner so that an operation of a Detector or Manual Call Point Hooters will sounded on the same floor and immediate alternate floor.

Air Conditioning System (If any):

18. The A.H.U. shall be separated for each floor with the system Air Ducts for individual floors.

19. Arrangement shall be made for isolation at the strategic locations by incorporating auto dampers in the Air Conditioning system.

20. The system of auto shut down of A.H.U. shall be incorporated with the auto detection and alarm system.

21. The air handling units room shall not be used for storage of any combustible materials.

First Aid Fire Fighting System:

22. First Aid Fire fighting arrangement in the style of placing suitable type of portable Fire Extinguishers, Fire Buckets etc. in all floors and vulnerable locations of the premises shall be made in accordance with I.S. 2190 – 1992.

General Recommendations:

3. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.

4. Provision of ventilation at the crown of the central core-duct of the building shall be provided.

5. Arrangements shall have to be made for sealing all the vertical ducts by the materials of adequate Fire resisting capacity.

Open Space & Approach:

6. The open space surrounding the building shall conform the relevant building rules as well as permit the accessibility and manoeuvrability of Fire appliance with turning facility.

7. The approach roads shall be sufficiently strong to withstand the load of Fire Engine weighting up to 20 M.T.

8. The width and height of the access gates into the premises shall not be less than 4.5 – 5 Mtr respecting abutting the road.

Fire Fighting Water:

9. Underground water reservoir having water capacity at 10,000 ltrs. and overhead reservoir of 5,000 ltrs. capacity exclusively for Fire fighting purpose with replenishing arrangements @ 1000 ltrs./min. Preferably from two different sources of water supply shall be provided. The water reservoir shall have overflow arrangement with the domestic water reservoir as well as to avoid stagnancy of water. The water reservoir shall be kept full at all time.

Hydrant System:

10. The building shall be provided with down comer through a 10 H.P booster pump, & 100mm internal diameter pipe line with provision of landing valves at the Staircase landings/half landings at the rate of one such riser for 1000 Sq m of floor area. The system shall be so designed that shall be kept charged with Water all the time under pressure and capable to discharge 1850 ltrs /min at the ground floor level outlet and minimum 900 ltrs/min at the top most outlet. In both cases the running pressure shall not be less than 3.5 Kgs/Cm². All other requirements shall conform I.S. 3844-1989.

11. Provision for Hose Reel in conjunction with down comer shall be made at each floor level conforming the relevant I. S. Specifications Provision for down comer shall be made at each floor level. Conforming the relevant I. S. Specifications.

Electrical Installation & Distribution:

12. The electrical installation including transformers, Switch Gears, Main & Meters etc. And the distribution system of the premises shall be made satisfying the code of

23. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.

24. Floor numbers and directional sign of escape route shall be displayed prominently.

25. The security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.

26. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.

27. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.

28. This shall be tested as provisional N.O.C. On compliance of all the above Fire and Life safety recommendations, the Director General, West Bengal Fire & Emergency Services shall be approached for necessary inspection and testing of the installation, Final N.O.C. in favour of the occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the building.

29. N.B.: Any deviation and changes the nature of use of the building in respect of the approved plan drawing, without obtaining prior permission from this office, this provisional N.O.C. will be treated as cancelled.

Signature valid

Digitally signed by NITAI
CHATTOPADHYAY
Date: 2020.03.05 18:54:54 IST

Divisional Fire Officer
West Bengal Fire & Emergency Services