



**Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16**

Memo no.:FSR/0125186231200705

Date: 29-11-2023

From:
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: RDB Meba Builders LLP
Mouza - Uttarbhag, JL No - 113, Under Ramnagar Panchayet, PO - Ramnagar, PS - Baruipur. Dist - South 24 Parganas. PIN - 743387

Sub: Fire Safety Recommendation for a proposed construction comprising G+I storied Type I – 234 no's, G+I storied Type II – 177 no's, G+I storied Type III – 174 no's, G+II storied Bungalow – 76 no's, G+III storied – 40 no's, commercial block of B+G+III storied & club house B+G+II storied having common basement under group Residential Building in the name of RDB Meba Builders LLP at Mouza - Uttarbhag, JL No - 113, Under Ramnagar Panchayet, PO - Ramnagar, PS - Baruipur. Dist - South 24 Parganas. PIN – 743387

This is in reference to your application no. 0125186231200705 dated 02-10-2023 regarding the Fire Safety Recommendation for a proposed construction comprising G+I storied Type I – 234 no's, G+I storied Type II – 177 no's, G+I storied Type III – 174 no's, G+II storied Bungalow – 76 no's, G+III storied – 40 no's, commercial block of B+G+III storied & club house B+G+II storied having common basement under group Residential Building in the name of RDB Meba Builders LLP at Mouza - Uttarbhag, JL No - 113, Under Ramnagar Panchayet, PO - Ramnagar, PS - Baruipur. Dist - South 24 Parganas. PIN – 743387

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this is issuing Fire Safety Recommendation in favor of the aforesaid building subject to the compliance of the following fire safety measure.

Recommendation:

CONSTRUCTION:

- 1.The whole construction of the proposed Building shall be carried out as per approved plan drawings conforming the relevant building rules of local Municipal Body / competent authority.
- 2.The floor area exceeds 750m² shall be suitably compartmented by separation walls up to ceiling level having at least two hours Fire resisting capacity.
- 3.The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
- 4.Provision of ventilation at the crown of the central core-duct of the building shall be provided. 5.Arrangements shall have to be made for sealing of all the vertical & horizontal ducts by the materials of adequate Fire resisting capacity at each

floor.

OPEN SPACE & APPROACH:

- 1.The open space surrounding the building shall conform the relevant building rules as well as permit the accessibility and manoeuvrability of Fire appliance .
- 2.The approach roads, internal road / driveway and dedicated clear open space as shown shall be sufficiently strong to withstand the load of Fire Engine weighing up to 45 M.T.
- 3.The width and height of the access gate into the premises shall not be less than 5M & 5.5 M respecting the abutting road.

STAIRCASE:

All the staircase of the building shall be negotiable to each other in each floor without entering into any room and shall be extended up to respective terrace. The roof of the stair wall shall be 1M above the surrounding roof area.

The width of the staircases and corridor and travel distance of different categories of occupancies shall have to conform the relevant building rules.

Fire and Smoke check doors at each the entrances of all the Staircase enclosures marked in the plan at each floor level shall be provided. The F.C.D. shall be of at least 2(two) hour Fire resisting wire glass window fitted with self-closing type open able in the direction of escape.

Considering the staircases are only means of evacuation, emergency lighting arrangement directional, exit, sign etc. shall be made conforming the relevant I.S. Code in this regard.

EXIT:

- 1.No exit door from any occupancy of any floor in a distance is not more than the distance as specified in N. B. C. –Part – IV, 2016. The travel distance to an exit from dead end of a corridor shall not exceed 6 mtr.
- 2.Exits shall be so arranged that at least two separate exits are available in every floor area. Exits shall be as remote from each other as practicable and so arranged that there are no pockets or dead end occurred in which occupants may be trapped.
- 3.Every exit door way shall open into an enclosed stairway or a horizontal exit of a corridor.

BASEMENT:

- 1.The basement shall be adequately ventilated.
- 2.Additional staircase from the open air as shown in the drawing shall be constructed beside the ramps conforming relevant I.S. Specification.
- 3.The basement shall be protected with Auto Sprinklers system/ hose reel system, landing valves etc.
- 4.Mechanical extractor for Smoke Venting system with the help of sufficient number of Jet Fans & co- axial fans from basement levels shall also be provided. The system shall be of such design as to operate on actuation of C.O sensor or sprinkling. It shall also have an arrangement to start it manually.
- 5.Mechanical extractors shall have an alternative source of supply.

MULTI-LAYER AUTOMATED MECHANIZED CAR PARKING SYSTEM:

1.Structural design: - The M.L.C.P. shall be constructed of structural steel construction.

Vertical Deck Separation: - For M.L.C.P. having Multi Car Parking level, vertical Fire separation between the upper and lower decks by using a non-perforated and non-combustible materials (Structural Steel Plate) shall be provided. This is to minimize direct impingement of flame to the Car in the upper deck and also to prevent dripping of any possible leaking fuel

to the lower deck. Proper drainage system shall have to be provided for accidental leaking of oil from the car and sand bed shall be provided at the ground level.

3.Fire Engine Accessway: - Accessway shall be provided for the Fire Engine to gain access to the car park entrance and exit.

4.Fire Hydrant: - Fire hydrants are to be provided in accordance with Cl. 4.4

5.Natural Ventilation: -Each car parking deck shall be provided with at least 50% external ventilation openings of the perimeter wall areas and uniformly distributed.

6.Sprinkler & Detection System: - Open Modular Type Sprinkler along with detectors shall be provided in all M.L.C.P. areas as per relevant I.S. Specification.

7.Cross zone wise sprinkler system shall have to be implemented.

1.Fire Pump: - Separate Jockey and Sprinkler pump of suitable capacity shall have to be installed for the M.L.C.P.

2.Operating System: - Both Mechanical and Manual type operating system shall have to be provided.

LIFT:

1.The walls of the lift enclosure of the buildings shall be at least two hours FIRE resisting type as pre-existing norms and provision of NBC Part IV, 2016.

2.The lift of the buildings shall be designed at high speed "Fire Lift" and shall be conspicuously indicated / marked.

3.The Electric power shall be from separate supply mains in the building and cables run with in the lift shafts, light and fans in the lift cars shall be operated from 24 volts, supply on emergency in case of failure of normal power supply lift shall automatically trip over alternate power supply.

5.Exit doors of the lift lobby shall be through a self- closing smoke stop door of 1 hour fire resistance for Residential Towers.

6.The speed of the fire lifts in the building shall be such that it can reach the top from the ground floor within 1 minute in visual indications of floor numbers shall incorporated in the lift cars.

7.All other requirements shall conform the I.S. specification including the communication facility in the lift cars connecting to the Fire Control Room of the building

FIRE FIGHTING WATER:

1.Underground water reservoirs having total water capacity of not less than 150,000 ltrs for shall be provided exclusively for firefighting purpose. Provision for use water from dedicated water body also to be provided in case of emergency.

2.Overhead reservoir of not less than 10,000 ltrs. Capacity exclusively for firefighting purpose on 'i.e., - commercial block & club house shall be kept full at all time.

3.The water reservoirs shall have overflow arrangement with the domestic water reservoirs as well as to avoid stagnancy of water.

4.Provision of necessary manhole shall be made on the top of these reservoirs as per specification.

5.Provision of replenishment at the rate of at least 2000 lts./min. from two separate sources of water supply shall be made.

6.The deep tube wells for the replenishment of the reservoirs shall be incorporated with auto starting facility with actuation of auto detection and suppression arrangement of the premises and shall also be connected with dual power supply units.

7.Provision of placing Fire Appliances near the underground water reservoir to be made to draw water in case of emergency.

WATER LAYOUT SYSTEM:

1.The buildings shall be provided with Wet Riser cum down comer of 100 mm. internal diameter Pipe Line with provision of landing valves at the Staircase landings / half landings at the rate of one such riser for 1000 Sq.m. of floor area. And Wet Riser cum down comer of 150 mm. internal diameter Pipe Line with provision of landing valves at the Staircase landings / half landings at the rate of one such riser for 1000 Sq.m. of floor area for commercial block and club house block.

2.The system shall be so designed that shall be kept charged with Water all the time under pressure and capable to

discharge 2850 lts/min. at the ground floor level outlet and minimum 900 lts/min. at the top most and furthest outlet. In both cases the running pressure shall not be less than 3.5 Kgs/Sq.cm. All other requirements shall be conforming I.S. 3844 – 1989.

2. Provision for delivery hose in hose box with short branch, Hose Reel units with high pressure gun on swivelling drum in conjunction with Wet Riser shall be made near landing valves of each floor, each block.

3. Yard Hydrant / Ring Main Hydrant of 150 mm with provision of adequate numbers of Pillar type Hydrant shall be installed surrounding the entire establishment in accordance with relevant I.S. specifications.

4. Provision of suitable Fire Service Inlet shall be made as per relevant I.S specification.

FIRE PUMP:

•Provision of the multi stage, multi outlet Fire Pump shall have to be made to supply water at the rate-designed pressure and discharge into the Water based system which shall be installed in the respective pump room for Residential Towers. One such pump shall always be kept on stand-by arrangement by diesel driven type. Provision of separate Jockey Pumps shall also have to be made to keep the Water based suppression systems i.e., hydrant and sprinkler system under pressurized condition at all the time. All the pumps shall be incorporated with both manual and auto starting facilities. The suction of pumps shall preferably of positive type or in case of negative suction the system shall be wet riser-cum-down comer with suitable terrace pump with overhead tank.

•All fire pumps shall have to multi stage multi outlet type, furthest point pressure shall have to maintained at least 3.5 kg.

•Jockey for hydrant-180 LPM

•Hydrant Main Pump – 2850 LPM

•Stand by (Diesel driven) -2850LPM

•Sprinkler Pump – 2850 LPM

SPRINKLER INSTALLATION:

1.The automatic Sprinkler installation separately of 150mm dia shall be provided in all floor areas of the Commercial block and Club house block including common basement as per I.S. 9972. Alarm gong to be incorporated along with the sprinkler system.

ELECTRICAL INSTALLATION & DISTRIBUTION(SUBSTATION):

1. The electrical installation including transformers, Switch Gears, L. T., H. T. Rooms, panel rooms, Main & Meters etc. and the distribution system of the premises shall be made satisfying the code of practice for Fire safety in general building as laid down in I.S. specification 1946 – 1982.

2. The vertical & horizontal ducts shall be sealed at all floor level by approved fire resisting materials.

3. The electrical installation shall be adequately protected with automatic fire detection and suppression system as per provision of N. B. C. Part– IV, 2016 and relevant I. S. specification.

4. Alternative Power Supply: Arrangements shall have to be made to supply power with the help of a generator to operate at least the Fire Pump, Pump for deep Tube-well, Fire Detection and Alarm System, signage etc. and also for illuminating the Staircase, corridors etc. and other places of assembly of the building in case of normal power failure.

5. High Velocity water Spray projector system to be provided for electrical substation.

HIGH VOLTAGE ELECTRIC LINE: -

1.No building, or veranda, or balcony or projection in any building shall be permitted to be erected, re-erected, added to or altered, in any case where the distance between such construction and any overhead electric lines, in accordance with the provision of the Electricity Act, 2003 (36 of 2003),

2.Vertical clearance of 2.5 mtr & horizontal clearance of 1.2 mtr shall have to maintained for Low and medium voltage lines including service lines

3.Vertical clearance of 3.7 mtr & horizontal clearance of 1.2 mtr shall have to maintained for High voltage lines up to and including 11,000 volts

4.Vertical clearance of 3.7 mtr & horizontal clearance of 2 mtr shall have to maintained for High voltage lines above 11,000 volts and up to and 3.7 m 2.0 including 33,000 volts

5.Vertical clearance of 3.7 m plus 0.3 m for every additional 33,000 volts or parts thereof & horizontal clearance of 2 mtr plus 0.3 m for for every additional 33,000 volts or parts thereof shall have to maintained for For extra high voltage lines beyond 33,000 volts.

DETECTION & ALARM SYSTEM:

1.Manually operated Electrical Fire Alarm system with at least 5 numbers of break glass type call boxes fitted with Hooters along with public address system, at each floor connecting with visual panel board shall be made in Control Room. The Control Room shall be located at the entrance of Ground Floor of the building, other requirements of the system shall be made conforming I.S. 2189 – 1988.

2.Auto fire detection system with the help of heat and smoke detector shall be installed in all floor of. commercial block & club house block. The system shall also be made in places of rooms where valuable articles have been kept. The other requirements of the system shall be made in accordance with I.S. 2189-1988.

3.Hooter will be sounded in such a manner so that on actuation of a Detector or Manual Call Point Hooters will be sounded on the same floor and immediate alternate floor.

4.Public Address System: -

Public address system shall have to be provided and linked between all floors and Control Room with talk back facility.

INTELLIGENCE SYSTEM:

1.Auto Fire Alarm System with analogue addressable smoke / Heat detector as per suitability shall be installed in each floor. Of commercial area, assembly area.

2.Addressable analogue manual call boxes incorporating with sounders shall be installed in all floors area of the building in such a manner that maximum travel distance shall not be more than 22.5 mtrs. in order to reach any of the call point.

3.Micro Processor based fire alarm panel shall be installed and all shall also be connected with main panel at the Fire Control Room of the premises having direct dialing facility to the local fire service unit.

4.Both way public address systems shall be made available in all floors of the building. The system shall be connected to the Main Control Room.

5.All the installations shall also be satisfying the I.S. specifications 2189 (as amended) and the code of practice as laid down in the N.B.C. Part-IV.

AIR CONDITIONING SYSTEM (IF ANY):

1.The A.H.U. shall be separated for each floor with the system Air Ducts for individual floors.

2.Arrangement shall be made for isolation at the strategic locations by incorporating auto dampers in the Air Conditioning system.

3.The system of auto shut down of A.H.U. shall be incorporated with the auto detection and alarm system.

4.The air handling units' room shall not be used for storage of any combustible materials.

5.Escape route like staircase, common corridors, lift lobby etc. shall not be used as return air passage.

6.Wherever the ducts pass through Fire wall of floors, the opening a rounding the ducts shall be sealed with Fire resisting

materials such as asbestos rope vermiculite concrete etc.

7.The metallic ducts shall be used even for the return air instead of space above the false ceiling.

8.The materials used for insulating the duct system (inside or outside) shall be of non-combustible materials glass wool shall not be wrapped or secured by any materials of combustible nature.

9.Area more than 750 sq. m. on individual floor shall be segregated by a Fire wall and automatic fire damper for isolation shall be provided.

10.Air duct services main floor area, corridors etc. shall not pass through the staircase enclosures.

11. The air handling units shall be separation for each floor, and air ducts for every floor shall be separated and in no way interconnected with the ducting of any other floor.

12.If the air handling units serve more than 1 floor, the recommendation given above shall be complied with in addition to the conditions given below: -

a) Proper arrangements by way of automatic Fire dampers working on fuse able link for isolating all ducting at every floor from the main riser shall be made.

b) When the automatic Fire alarm operates the respective air handling units of the air conditioning system shall automatically switched off.

13.The vertical shaft for treated fresh air shall be of masonry construction.

14.The air filters for air handling units shall be of non-combustible materials.

15.Inspection panel shall be provided in the main trucking to facility the cleaning of ducts of accumulated dust and to obtain access for maintenance of fire dampers.

16. No combustible materials shall be fixed nearer than 15cm to any duct unless such duct properly enclosed and protected with non-combustible materials (glass wool or Spun wool with neoprene facing enclosed and wrapped with aluminium sheeting) at least 3.2m thick. And which would not readily conduct heat.

17. FIRST AID FIRE FIGHTING SYSTEM: First Aid firefighting arrangement in the style of placing suitable type of portable Fire Extinguishers, Fire Buckets etc. in all floors and vulnerable locations of the premises shall be made in accordance with I.S. 2190 – 1992.

GAS BANK (IF ANY)

1.Safe distance between L.P.G storage (Gas Bank) and any other structure of occupancies should be maintained as per explosive rule

2.Gas cylinder Rule- 1981 to be followed strictly.

3.Gas Detector to be installed inside the gas bank to detect the leakage of gas. If any, before reaching to the fuel air mixture suitable for combustion.

4.The storage room and shed should be Fire Resistance construction.

5.Cylinders shall not be along with any combustible material.

6.The storage shed shall be adequately ventilated near the ground level & ventilators near the roof to be provided with cover with two layer of brass wire gauge of eleven meshes per linear centimetre. Ventilation should not be less than five percent (5%) of the total floor area.

7.No electric wiring/fitting to be allowed to install inside the gas bank.

8.The floor of the gas bank should be non-sparking type as per Explosive Rule.

9.Design, fabrication of the pipe line /connection/couplings/protective arrangements shall be as per recognized design code of manufacturer's recommendation.

10.Mechanical integrity of pipe line /fitting etc shall be obtained from a competent person/agency.

11.“Action in case of Fireboard must be displayed on conspicuous places.

12.All the charged cylinder should be connected with manifolds.

13.Installation and handling of cylinders should be done by trained and responsible persons who know the characteristic of Liquefied Petroleum Gas.

14. All the cylinders should be upright with the valves uppermost.
15. "No Smoking" Board should be displayed around the Gas bank.
16. Gas pipe line should be run in separate shaft and shall be installed on the external wall and the L.P.G distribution pipes shall always be below the false ceiling; an isolation valve shall be provided outside the gas bank and within the man height.
17. Automatic sprinkler system shall be installed inside the Gas Bank as per requirement and adequate number of hydrants point also to be installed nearby, maintaining a safe distance from the L.P.G Bank.
18. Portable Fire extinguishers shall be provided near the Gas Bank area.

Fire Kiosk:

1. Fire Kiosk shall be at the entrance of the project having direct access. The control room shall have
2. the main Fire alarm panel with communication system (suitable public address system) to aid floors and facilities for
3. receiving the message from different floors. Fire Kiosk shall be constructed with 120 min. rating walls with a fire door and
4. shall be provided with emergency lighting. Interior finishes shall not use any flammable materials. All controls and
5. monitoring of fire alarm systems, pressurization systems, smoke management systems shall happen from this room.
6. Monitoring of integrated building management systems, CCTVs or any other critical parameters in building may also be
7. Details of all floors plans along with the details of Fire Fighting equipment and installations (2 sets laminated and bound)
8. shall be maintained in Fire Kiosk. In charge of the Fire Kiosk shall also be responsible for the maintenance of the various
9. Services and Fire Fighting equipment and installations in co-ordination with security, electrical and civil staff of the entire premises.

GENERAL RECOMMENDATION:

1. Obtain Fire Service License before regularizing the gas bank.
2. Disposable type B. A. Musk to be kept always for emergency fire situation.
3. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.
4. Floor numbers and directional sign of escape route shall be displayed prominently.
5. The occupants and security staff shall be conversant with installed Fire Fighting equipment's of the building and able to operate in the event of Fire and Testing.
6. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.
7. A crew of trained Fireman under an experienced officer shall be maintained round the clock for safety of the building.
8. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
9. Fire License shall have to be obtained from this Department after compliance of the above Safety Recommendations before commissioning of the Gas Bank.
10. Each year a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements and installation of the building.

On compliance of all the above Fire and Life safety recommendations, the Director General, West Bengal Fire &

Emergency Services shall be approached for necessary inspection and testing of the installation, Fire Safety Certificate in favor of the occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the building.

N.B.:Any deviation and changes the nature of use of the building in respect of the approved plan drawing, without obtaining prior permission from this office, this Fire Safety Recommendation will be treated as cancelled.

Signature Not Verified
Digitally signed by ABHIJIT
PANDEY
Date: 2023.11.29 13:02:39 IST

DIRECTOR
West Bengal Fire & Emergency Services

Memo No.:FSR/0125186231200705