

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D Mirza Ghalib Street, Kolkata- 700 016**

Memo No : IND/WB/FES/20182019/37194

DATE: 28/02/2019

From :

The Director

Fire Prevention Wing,

West Bengal Fire & Emergency Services.

To :

Amit Jhunjunwala [Self &, C. A. of 03 Others']

82 A, Nimtola Ghat Street.

Nimtala F.S., Burtolla,

Kolkata - 700006 .

Sub :Revised Fire Safety Recommendation for proposed B+G+IV storied under group residential Building at premises no.- 82 A, Nimtola Ghat Street, Ward No. : 20, Kolkata : 700006, Borough No. II.

This is in reference to your Application No. IND/WB/FES/20182019/37194,dated 28/02/2019, regarding the Fire Safety Measureendation for proposed B+G+IV storied under group residential Building at premises no.- 82 A, Nimtola Ghat Street, Ward No. : 20, Kolkata : 700006, Borough No. II.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this is issuing Fire Safety Recommendation in favour of the aforesaid building subject to the compliance of the following fire safety measure.

Recommendation:

1. The revised plan submitted by you was scrutinized and marked as found necessary from fire safety point of view. In returning one set of plan, this office is approved Revised Plan Drawing in favour of the aforesaid building subject to the compliance of the fire safety measure as recommendation issued earlier vide this office memo no. WBFES/6286/13/KOL – R3/1243/13(1243/13), Date :- 19/11/2013. remain same & strictly to be followed. In addition to above sprinkler to be installed at corridor in each floor.

Director
West Bengal Fire & Emergency Services