

To,  
The Director,  
Arch Infra Properties Pvt. Ltd.,  
99A, Park Street, Siddha Park,  
5<sup>th</sup> Floor, Kolkata – 700 017.

Sub : NOC to the proposed (B+G+X) storied residential housing complex at Dag No. – 140, 141 of Mouza – Atghara, Ward No. – 09, Chinar Park, Kolkata - 136 under Rajarhat-Gopalpur Municipality.


Ref. : Your letter no. – NIL dt. – 12.06.2014.

Sir,

With reference to the above it is to inform you that for potable water you may avail supply from the existing pipe line as per as capacity available and you can also install the deep tubewell after having necessary permission from SWID. The Municipality may take the solid waste from your project provided the cost for strengthening the infrastructure for primary and secondary transfer of municipal solid waste from the project to the dumping ground will be borne by you.

You are also advised to install STP followed by tertiary treatment to reduce the BOD level less than 5mg/ltr. and to use the major part of the treated waste water in the development of utilities like car wash, landscape and flushing. The surplus of treated waste water may be discharged to municipal drain.

Yours faithfully,

  
(CHAIRMAN)  
Rajarhat-Gopalpur Municipality

Copy to :-  
1. Assistant Engineer, R.G.M.

(CHAIRMAN)  
Rajarhat-Gopalpur Municipality