



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:FSR/0125186211100283

Date: 01-07-2021

From:
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: Naoolin Realcon Pvt Ltd Director Sri Debashis Roy
PROPOSED RESIDENTIAL COMPLEX COMPRISING OF 6 NOS. OF RESIDENTIAL BUILDING (G PLUS7) 25.4 MT.
HT. AT MOUZA:CHAPNA, PATHARGHATA ,DAG NO.151,3187,3196,3192,3194,3191,3191/3815,3195 KHATIAN NO.
AS GIVEN IN DRAWING. JL NO. 35, 36 UNDER G.P-PATHARGHATA, P.S-NEWTOWN, DIST NORTH 24 PARGANAS.

Sub: Fire Safety Recommendation for proposed Residential Complex Comprising of 4 Nos of Residential Building (G+7) Storied and 01 No of Mixed use building (G+7) At premises no:--- Mouza- Chapna, J.L.No- 35, Comprised in R.S./L.R.Dag No- 151, under L.R.KhaitianNos- 1016, 1018, 1019, 1020, 1021, 1022, 1023, 1024, 1025, 1026, 1027, 1028,1029,1030,1031,1059 Mouza- Patharghanta, J.L.No- 36, Comprised in R.S./L.R. Dag Nos- 3187, 3191, 3191/3815, 3192, 3194, 3195, 3196, Under L.R.Khatian Nos- 5779, 6114, 6524, 6526, 6149, 6141, 5801, 5784, 5904, 5899, 6150, 6146, 5805, 6129, 6128, 6127, 6125, 6126, 6144, 6131, 6143, 6145, 6130, 6574, 6360, 5902, 6575, 5780, 6359, 6148, 5901, 5803, 6362, 6355, 6361, 6357, 6356, 5903, 6358, 2745, 2747, 6826, 6827, 6828,6829 ,6164, 6165, 6816, 6818, 6821, 6820, 5802, 6819, 6817, 6823, 6824, 6151, 6132, 6140, 6525, 5900, 5804, 6163, 6133, 6142, 6124, 5898, 2740, 6970, 6969 Under Patharghanta Gram Panchayet, P.S.- New Town, District- North 24 Parganas,West Bengal

This is in reference to your application no. 0125186211100283 dated 26-03-2021 regarding the Fire Safety Recommendation for proposed Residential Complex Comprising of 4 Nos of Residential Building (G+7) Storied and 01 No of Mixed use building (G+7) At premises no:--- Mouza- Chapna, J.L.No- 35, Comprised in R.S./L.R.Dag No- 151, under L.R.KhaitianNos- 1016, 1018, 1019, 1020, 1021, 1022, 1023, 1024, 1025, 1026, 1027, 1028,1029,1030,1031,1059 Mouza- Patharghanta, J.L.No- 36, Comprised in R.S./L.R. Dag Nos- 3187, 3191, 3191/3815, 3192, 3194, 3195, 3196, Under L.R.Khatian Nos- 5779, 6114, 6524, 6526, 6149, 6141, 5801, 5784, 5904, 5899, 6150, 6146, 5805, 6129, 6128, 6127, 6125, 6126, 6144, 6131, 6143, 6145, 6130, 6574, 6360, 5902, 6575, 5780, 6359, 6148, 5901, 5803, 6362, 6355, 6361, 6357, 6356, 5903, 6358, 2745, 2747, 6826, 6827, 6828,6829 ,6164, 6165, 6816, 6818, 6821, 6820, 5802, 6819, 6817, 6823, 6824, 6151, 6132, 6140, 6525, 5900, 5804, 6163, 6133, 6142, 6124, 5898, 2740, 6970, 6969 Under Patharghanta Gram Panchayet, P.S.- New Town, District- North 24 Parganas,West Bengal

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this is issuing Fire Safety Recommendation in favor of the aforesaid building subject to the compliance of the following fire safety measure.

NAOOLIN REALCON PRIVATE LIMITED

Debashis Roy

Director

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125186211100283.

Page : 1

Recommendation:

(A) CONSTRUCTION:

- The whole construction of the Proposed buildings shall be carried out as per approved plan drawings conforming the relevant building rules of local Municipal Body.
- The floor area exceeds 750 m² shall be suitable compartmented by separation walls up to ceiling level having at least Two hours Fire resisting capacity.
- The interior finish decoration of the building shall be made of low flame spread materials conforming to I.S. specifications.
- Provision of ventilation at the crown of the central core-duct of the building shall be provided.
- Arrangements shall have to be made for sealing all the vertical & horizontal ducts by the materials of adequate Fire resisting capacity & the doors of service ducts / shafts of 2hr. Fire rating.

(B) OPEN SPACE & APPROACH:

- The open spaces surrounding the building shall conform the relevant building rules as well as permit the accessibility and maneuverability of Fire Appliances with turning facility.
- The approach road shall be sufficiently strong to withstand the load of Fire Engine weighting up to 45 M.T.
- The width and height of the access gates into the premises shall not be less than 4.5 and 5 M respecting abutting the road.

(C) STAIRCASE:

- The staircase of the building shall be enclosed type. Entire construction shall be made of bricks / RCC type having Fire Resisting Capacity not less than 4 hours.
- The staircase of the building shall have permanent vents at the top and open able sashes at each floor level in the external wall of the building.
- The width of the Staircase shall be made as shown in the plan. Corridors and the exit doors shall conforming the relevant building rules and well as rules of the cinematograph act, with up to date amendments.
- All the staircases shall be extended up to terrace of the building and shall be negotiable to each other without entering into any room.
- Fire & Smoke doors at the entrance of all the staircase enclosures as shown/marked in the plan at each floor level shall be provided. The F.C.D. shall be of the least one two hours Fire resisting Wire Glass Window fitted with self closing type openable in the direction of escape.

NAOLIN REALCON PRIVATE LIMITED

The authenticity of this document can be verified by accessing the URL: edistrictwb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125186211100283.

Page : 2

Director

Powered By



For secure paperless solutions
Please visit www.emsigner.com

(D)LIFT :-

- The walls of the lift enclosure shall be at least two hours Fire Resisting type.
- Collapsible gate shall not be permitted.
- One of the lifts shall be designed for Fire Lift. The word "Fire Lift" shall conspicuously be written at ground floor.
- In case of failure of normal electric supply, it shall automatically trip of alternate supply and also shall have manually operated change over facility. Alternatively, the lift shall be so wired that in case of power failure, it comes down at ground level stands still with door open.
- All other requirements shall confirm the I.S. specification including the communication facility in the lift cars connecting with the Fire Control Room of the building.

(E)FIRE FIGHTING WATER :

- Underground water reservoir having water capacity of 100000 Ltrs. and O.H.W.R. 5000 ltrs at each Block capacity exclusively for firefighting purpose shall be kept full at all time.
- The Fire water reservoir shall have overflow arrangement with the domestic water reservoir as well as to avoid stagnancy of water.
- Provision of necessary manhole shall be made on the top of this reservoir as per specification.
- Provision of replenishment at the rate of at least 2000 ltrs./min. from two separate source of water supplies shall be made.
- The deep tube wells for the replenishment of the reservoir shall be incorporated with auto starting facility with actuation of auto detection and suppression arrangement of the premises and shall also be connected with dual power supply units.
- Provision of placing Fire Appliances on the underground water reservoir to be made to draw water in case of emergency.

(F)WATER LAYOUT SYSTEM:

- The building shall be provided with wet riser with 150mm. internal diameter Pipe Line with provision of Hose Reel Hose at the Staircase landings / half landings. The system shall be so designed that shall be kept charged with Water all the time under pressure All other requirements shall conforming I.S. 3844 – 1989.
- Provision for Hose Reel units on swiveling drum in conjunction with Wet Riser cum Down Comer shall be made near each

loading valves.

- Ring Main Hydrant with provision of adequate numbers Hydrant shall be installed surrounding the building in accordance with relevant I.S. specifications.
- Two fire service inlet near the entry or exit of the premises facing to the abutting road/roads shall have to be provided.
- All the assembly area along with annicilliary part thereof , Mercantile area floors shall have to be provided with Auto-sprinklers and Auto Detection system

FIRE PUMP:

- Provision of the Fire Pump shall have to be made to supply water at the rate-designed pressure and discharge into the Water based system, which shall be installed in the building. One such pump shall always be kept on stand-by be of diesel driven type.
- Provision of Jockey Pump/Stand by Pump shall also have to be made to keep the Water based system under pressurized condition at all the time. All the pumps shall be incorporated with both manual and auto starting facilities. The suction of pumps shall preferably of positive type or in case of negative suction the system shall be wet riser-cum-down comer with suitable terrace pump with overhead tank.
- The Discharge Capacity of Jockey shall have to be 180LPM considering other IS specification.
- The Discharge Capacity of Main shall have to be 2850 LPM considering other IS specification.
- The Discharge Capacity of Stand by shall have to be 2850 LPM considering other IS specification.
- The Discharge Capacity of Diesel driven fire pump shall have to be 2850LPM considering other IS specification.

AUTO Matic SPRINKLER INSTALLATION:--

- 1.The automatic sprinkler installation shall be provided at corridors of each block and in commercial area (mercantile and business area) of the building as per I.S.9972. Alarm Gong to be incorporated along with the sprinkler system.
- 2.In area having height 17 M or above, sprinkler installation may be rendered ineffective and may be avoided, separate appropriate firefighting installation system for the protection of those areas shall have to be installed.
- 3.Pressure in sprinkler system shall not exceed 12 bar or else high pressure sprinkler to be installed for above 12 bar operation.

(G)DETECTION AND ALARM SYSTEM:

- Manually operated Electrical Fire Alarm system at each floor level with at least three numbers of break glass type call boxes fitted with Hooters along with public address system, at each floor connecting with audio-visual panel board shall be made in Control Room. The Control Room shall be located at the entrance of Ground Floor of the building, other requirements of the system shall be made conforming I.S. 2189 – 1988.
- Auto fire detection system with the help of Smoke Detectors shall be installed covering corridors of the proposed blocks and commercial floors, mercantile floors, of the buildings. The system shall also be made in place of rooms where valuable articles have been kept, The other requirements of the system shall be made in accordance with I.S. 2189-1988.

•Hooter will be sounded in such a manner so that an operation of a Detector or Manual Call Point Hooters will sounded on the same floor and immediate alternate floor.

•All floors of the Mixed occupancy Building shall have to be provided with Auto detection system having integrity with Fire Alarm Panel.

Public Address System:

•Public address system linked between all floors and control Room shall have to be established.

(H) ELECTRICAL INSTALLATION & DISTRIBUTION:

•The electrical installation including transformers, Switch Gears, Main & Meters etc. and the distribution system of the premises shall be made satisfying the code of practice for Fire safety in general building as laid down in I.S. specification 1946 – 1982.

•Electrical distribution system shall conform all the requirements as laid in I. S. 1646-1982.

•The electrical installation shall be adequately protected with automatic CO2/D.C.P.

•All electrical installation viz. Transformer Switch Gear L. T., H. T. rooms shall be protected with both auto detection and suppression systems as per suitability.

(I) Alternative Power Supply :

a. Arrangements shall have to be made to supply power with the help of a generator to operate at least the Fire Pump, Pump for deep Tube-well, Fire Alarm System, etc. and also for illuminating the Staircase, corridors etc. and other places of assembly of the building in case of normal power failure.

(J) DETECTION AND ALARM SYSTEM:

•Manually operated Electrical Fire Alarm system at each floor level with at least three numbers of break glass type call boxes fitted with Hooters along with public address system, at each floor connecting with audio-visual panel board shall be made in Control Room. The Control Room shall be located at the entrance of Ground Floor of the building, other requirements of the system shall be made conforming I.S. 2189 – 1988.

•Auto fire detection system with the help of Smoke Detectors shall be installed covering corridors of the proposed blocks and commercial floors, mercantile floors, of the buildings. The system shall also be made in place of rooms where valuable articles have been kept, The other requirements of the system shall be made in accordance with I.S. 2189-1988.

•Hooter will be sounded in such a manner so that an operation of a Detector or Manual Call Point Hooters will sounded on the same floor and immediate alternate floor.

NAOOLIN REALCON PRIVATE LIMITED

•All floors of the Mixed occupancy Building shall have to be provided with Auto detection system having integrity with Fire Alarm Panel.

(K)Public Address System :-

•Public address system linked between all floors and Control Room shall have to be established.

(L)FIRSTAID FIRE FIGHTING SYSTEM:

•First Aid firefighting arrangement in the style of placing suitable type of portable Fire Extinguishers, Fire buckets etc. in all floors and vulnerable locations of the premises shall be made in accordance with I.S. 2190-92.

•Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.

•Floor numbers and directional sign of escape route shall be displayed prominently.

•The occupancy and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.

•Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipments installed in the building to keep them in perfectly good working conditions at all times.


•A crew of trained Fireman under an experienced officer shall be maintained round the clock for safety of the building.

•Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.

On compliance of all the above Fire and Life safety recommendations, the Director General, West Bengal Fire & Emergency Services shall be approached for necessary inspection and testing of the installation, Fire Safety Certificate in favour of the occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the building.

N.B. :Any deviation and changes the nature of use of the building in respect of the approved plan drawing, without obtaining prior permission from this office, this Fire Safety Recommendation will be treated as cancelled.

NAOOLIN REALCON PRIVATE LIMITED


Director

Director
West Bengal Fire & Emergency Services

Director
West Bengal Fire & Emergency Services
100, New Alipore Street, Kolkata - 74

Memo No. FSR/0125186211100283

Date: 01/07/2021

To
Director
West Bengal Fire & Emergency Services

Subject
Reference
Date

Memo No.: FSR/0125186211100283

Signature valid

Digitally signed by ABHIJIT
PANDEY
Date: 2021.07.01 20:42:13 IST