



WBSEDCL

West Bengal State Electricity Distribution Company Limited

(A Government of West Bengal Enterprise)

TO WHOM IT MAY CONCERN


NOC against New Service Connection

This is to certify that safe distance is maintained from vertical & horizontal L & MV, HT overhead line against the L.R. Plot No- 556, L.R. Khatian- 3961, 3962, 3963, 3964, Mouza- Turki Sitarampur, J.L. No.- 100, Dist- Bankura in favour of Shree Laxmi Builders & Developers as per inspection dated on 05.06.2023.

The above mentioned land adhere safety rule of electrical overhead line.

A chart showing mandatory clearance from any exiting HV and L & MV overhead lines from any building as per Electricity Act, 2003 is reproduced below:-

| Mandatory clearance in Meter (Feet) | L & MV (up to 440 Volt) | HV (11 KV) | HV (33KV) |
|------------------------------------------------------------------------------------------------------|------------------------------------|---------------------|------------------|
| Vertical clearance of OH line from highest point of the building /structure (permanent or temporary) | 5.18 meter (17 feet) | 6.4 meter (21 feet) | N.A. |
| Horizontal clearance of line from nearest point of the building / structure(permanent or temporary) | 7 meter (23.1 feet) | 9 meter (29 feet) | N.A. |


05/06/23

**A.E. & Station Manager
Bishnupur CCC**

*A.E. & Station Manager
Bishnupur C.C.C.
Bishnupur, Bankura
W.B.S.E.D.C.L.*