



Government Of West Bengal
Office Of The Deputy Director
West Bengal Fire & Emergency Services
Station Feeder Road, P.O & P.S Sillguri,
District: Darjeeling, Pin - 734005

Memo no.:FSR/0125186220800078

Date: 26-05-2022

From:
Deputy Director
North Zone, HQ Wing,
West Bengal Fire & Emergency Services

To: Anjan Kumar Saha
Word no 9 , D.P.B. Sarani , Under English Bazar Municipality , Malda, Pin 732101

Sub: Fire Safety Recommendation of Proposed construction of (B+G+6) storied Residential Building under group of Residential in the name of Mr. Anjan Kumar Saha at the Premises no-Mouza-English Bazar,Plot No- RS 1037 & LR 1999,KH No- Sabek-336 & HAL 328, JL No-67, Word no 9 , D.P.B. Sarani , Under English Bazar Municipality ,P.S-English Bazar, Dist-Malda,Pin-732101.

This is in reference to your application no. 0125186220800078 dated 03-05-2022 regarding the Fire Safety Recommendation of Proposed construction of (B+G+6) storied Residential Building under group of Residential in the name of Mr. Anjan Kumar Saha at the Premises no-Mouza-English Bazar,Plot No- RS 1037 & LR 1999,KH No- Sabek-336 & HAL 328, JL No-67, Word no 9 , D.P.B. Sarani , Under English Bazar Municipality ,P.S-English Bazar, Dist-Malda,Pin-732101.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this is issuing Fire Safety Recommendation in favor of the aforesaid building subject to the compliance of the following fire safety measure.

Recommendation:
CONSTRUCTION

- 1.The whole construction of the proposed building shall be carried out as per approved plan drawing conforming relevant building rules of local Municipal body.
- 2.The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specification.
- 3.Provision of ventilation at the crown of the central core-duct of the building shall be provided.
- 4.Arrangement shall have to be made for sealing all the vertical ducts by the materials of adequate fire resisting capacity.

OPEN SPACE & APPROACH

The authenticity of this document can be verified by accessing the URL: edistrictwb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number: 0125186220800078. Page : 1

Digitally signed by Anjan Kumar Saha, DN: cn=Anjan Kumar Saha, o=West Bengal Fire & Emergency Services, ou=North Zone, email=anjan.kumar.saha@wbfire.gov.in, c=IN. For secure paperless solution.

portal using your login user id and password used for submission of the above application within 15 (Fifteen) days from the date of issue of this demand notice positively.

Signature Not Verified
Digitally signed by ABHJIT
PANDEY
Date: 2022.05.28 12:54:17 IST

Deputy Director
West Bengal Fire & Emergency Services