

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D Mirza Ghalib Street, Kolkata- 700 016**

Memo No : IND/WB/FES/20182019/28344

DATE: 08/07/2019

From :

**The Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services.**

To :

**R S KHETAN
25 NETAJI SUBHAS ROAD, WARD NO - 45, BOROUGH - V, P.S - HARE STREET,
KOLKATA - 700001.
Lalbazar F.S., Hare Street,
Kolkata - 700001 .**

Sub :Revised Fire Safety Recommendation for proposed construction of a G+XXXII storied Mega Business building having rooftop helipad facility, at premises no:- 25 NETAJI SUBHAS ROAD, WARD NO - 45, BOROUGH - V, P.S - HARE STREET, KOLKATA – 700001

This is in reference to your Application No. IND/WB/FES/20182019/28344,dated 08/07/2019, regarding the Fire Safety Measure for proposed construction of a G+XXXII storied Mega Business building having rooftop helipad facility, at premises no:- 25 NETAJI SUBHAS ROAD, WARD NO - 45, BOROUGH - V, P.S - HARE STREET, KOLKATA – 700001.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this is issuing Revised Fire Safety Recommendation in favour of the aforesaid building subject to the compliance of the following fire safety measure.

Recommendation:

1. The Fire Safety Recommendation which was issued from this office vide memo no-WBFES/4453/16/Complain/KOL/240/12(240/12) Date11/07/16 strictly to be followed except

OHWR for fire total 42275 lts capacity shall have to be provided and strictly to be maintained the national aviation Rules for helipad .

2. Fire pumps shall have to be provided multi stage & multi out let type as per requirement the volume of height of the building.

Director
West Bengal Fire & Emergency Services

Signature valid

Digitally signed by TARUN
KUMAR SINHA
Date: 2019.07.08 17:41:04 IST