



**ASHTA VINAYAK**  
INFRASTRUCTURE



191, C.R.Avenue, 3rd floor  
Kolkata - 700007



mail.avgroup@gmail.com



+9198 3687 7004  
+9191 3173 3638

To  
The Authority  
WBRERA  
Kolkata  
West Bengal

**Declaration of not requiring Noc from Fire Department**

According to the guidelines laid down by the Fire Department, West Bengal, it is not mandatory to obtain clearance from Fire Department for the project "AV Courtyard" as the project is G+4 storied building and is below 15 (fifteen) meters therefore Fire Department NOC is not required.

ASHTA VINAYAK INFRASTRUCTURE

*Vinay Gupta*

Partner

"DREAM TO REALITY"