

**TAPAS BHATTACHARJEE**

EBS. & LBS. (CLASS-1)

Registered Civil Engineer & Consultant Of  
Rajpur - Sonarpur Municipality, Baruipur  
Municipality, Kolkata Municipal Corporation &  
Zilla Parisad.

Associated Member of I.R.T. (Rly.) & Permanent Way Engineers Association (Rly.) India.

Ph. Res. 7044158790 & Address - Baruipur Duttapara, P.O. & P.S. - Baruipur, South 24 Parganas, West Bengal - 700144.

Date, 19.1.08.1.2024

Rgf. No. ....


**TO WHOMSOEVER IT MAY CONCERN**  
**ENGINEER CERTIFICATE REGARDING HEIGHT OF BUILDING**

This is to declare and certify that the height of the Building named "M.N. ROY APARTMENT" at 228, J.N. Bose Road, Near Kodalia School, P.O. - Kodalia, P.S. - Sonarpur, Ward No. 20 of RajpurSonarpur Municipality, Kolkata - 700147, WB, India is 14.46 Meteres and has not crossed the threshold limit for mandatory WBFIRE Clearance, i.e. 14.50 Meteres.

Although the PERMISSIBLE HEIGHT as mentioned in Sanction Plan is 15.50 Meteres, the Developer is constructing till 14.46 Meteres only.

I, the undersigned has verified the same as a Technically Qualified Professional and do hereby declare that the Project named "M.N. ROY APARTMENT" does not cross the threshold limit as per WBFIRE Rules.

I declare the above statement to be fully true and correct.

  
**Tapas Bhattacharjee (L.B.S. Class-I)**  
**B-Tech (Civil), DCE (Civil)**  
**Registered Civil Engineer and Consultant**  
**of Kol. MPL. Corporation, Rajpur-Sonarpur**  
**MPL, Baruipur MPL & Zilla Parisad (South)**  
**Mob : 7044158790**