



Government Of West Bengal  
Office Of The Deputy Director  
West Bengal Fire & Emergency Services  
Station Feeder Road, P.O & P.S Siliguri,  
District: Darjeeling, Pin - 734005

Memo no.:FSR/0125186227900045

Date: 17-02-2022

**From:**  
Deputy Director  
North Zone, HQ Wing,  
West Bengal Fire & Emergency Services

**To:** Ground With Five Storied Residential Cum Commercial Building of 1) Green Hill Venture, and 2) Silver Lake Distributors Pvt. Ltd.  
Shastri Nagar, Ward No.: 41 (S.M.C.) Mother Teresa Road, Plot No.: L.R. 138, R.S. 639, 640, Kh. No.: L.R. 659,710,711, R.S. 212, P.S.: Bhaktinagar, Dist.: Jalpaiguri.

**Sub:** Fire Safety Recommendation for Proposed construction of G + 5 Storied Commercial cum Residential Building under group of Residential in the name of 1) Green Hill Venture, and 2) Silver Lake Distributors Pvt. Ltd. at the Premises no- Shastri Nagar, Ward No.: 41 (S.M.C.) Mother Teresa Road, Plot No.: L.R. 138, R.S. 639, 640, Kh. No.: L.R. 659,710,711, R.S. 212, Mouza Dabgram, Sheet no- LR 44,RS 08, Holding no- 1162/B,P.S.: Bhaktinagar, Dist.: Jalpaiguri. Pin-734001

This is in reference to your application no. 0125186227900045 dated 09-02-2022 regarding the Fire Safety Recommendation for Proposed construction of G + 5 Storied Commercial cum Residential Building under group of Residential in the name of 1) Green Hill Venture, and 2) Silver Lake Distributors Pvt. Ltd. at the Premises no- Shastri Nagar, Ward No.: 41 (S.M.C.) Mother Teresa Road, Plot No.: L.R. 138, R.S. 639, 640, Kh. No.: L.R. 659,710,711, R.S. 212, Mouza Dabgram, Sheet no- LR 44,RS 08, Holding no- 1162/B,P.S.: Bhaktinagar, Dist.: Jalpaiguri. Pin-734001

**The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this is issuing Fire Safety Recommendation in favor of the aforesaid building subject to the compliance of the following fire safety measure.**

**Recommendation:**

**CONSTRUCTION**

- 1.The whole construction of the proposed building shall be carried out as per approved plan drawing conforming relevant building rules of local administrative body (Municipality/panchayat).
- 2.The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specification.
- 3.Provision of ventilation at the crown of the central core-duct of the building shall be provided.
- 4.Arrangement shall have to be made for sealing all the vertical ducts by the materials of adequate fire resisting capacity.

## OPEN SPACE & APPROACH

- 1.The open space surrounding the buildings shall conform the relevant building rules as well as permit the accessibility and manoeuvrability of fire appliances with turning facility having minimum 6.5 M width in each side.
- 2.The approach roads shall be sufficiently strong to withstand load of fire engine weighing up to 45 M.T.
- 3.The width and height of the access gates into the premises shall not be less than 4M and 5M respectively abutting the road.

## STAIRCASE

- 1)The staircase of the building shall be enclosed type. Entire construction shall be made of bricks/R.C.C. type having fire resisting capacity not less than 4 hours.
- 2)The staircase of the building shall have permanent vents at the top and open able sashes at each floor level in the external wall of the building.
- 3)The width of the staircase shall be made as marked in the plan. Corridors and the exit doors shall conforming the relevant building rules which upto date amendment.
- 4)All the staircases shall be extended upto terrace of the building and shall be negotiable to each other without entering into any room.

## LIFT

- 1)Walls of all lift enclosures shall have a fire rating of two hours; lifts shafts have a vent area not less than 0.2 M2
- 2)Lift Motor Room shall be located preferably on top of the shaft and separated from the shaft by the floor of the room.
- 3)Landing doors in all lift enclosures shall have a fire resistant of not less than 1 hour.
- 4)All Lift Car door shall have a fire resistance rating of half an hour.
- 5)Exit from the lift lobby, if located in the core of the building, shall be through a self closing smoke stop door of half an hour fire resistance.
- 6)Grounding Switch (es), at ground floor level shall be provided on all the lifts to enable the fire service to ground the lifts..
- 7)Collapsible gates shall not be permitted for lifts and shall have solid lift doors with fire resistance of at least 1h.
- 8)The number of lifts in one row for a lift bank shall not exceed 4 and the total number of lifts in the bank (of two rows) shall not exceed 8.A wall of 2h Fire rating shall separate individual shafts in a bank.
- 9)A sign shall be posted and maintained on every floor at or near the lift indicating that in case of fire, occupants shall use the stairs unless instructed otherwise. The sign shall also contain a plan for each floor showing the locations of the

stairways.

10) In case of failure of normal electric supply, it shall automatically trip over to alternate supply. This changeover of supply could be done through manually operated changeover switch. Alternatively, the lift shall be so wired that in case of power failure, it comes down at the ground level and comes to stand still with door open.

#### .FIRE FIGHTING WATER

The Centre shall have to be equipped with 50,000 lts. of underground stored water with replenishing arrangement @ 1000 lts./min preferably from two different sources of water supply.

Wet Riser System IS:3844

100 mm dia riser with single out let landing valve shall have to be provided.

Electrical Installation- shall be as per code of practice 1946: 1978, (NBC-Gr-iv) & Indian Electricity rules-1956 with up to date amendment. No electrical switch gear/ distribution should be installed below the staircase.

Pumps for fire fighting Installation (IS 12469:1988):-

i) The standard code of practice recommended that all water based fixed fire fighting installations should be fed by two separate automatic pumps, one of which should act as stand by. Each pump should be designed to deliver water at required pressure and discharge, taking into account the height and volume of the building.

ii) The Fire pumps should be provided near the underground static water storage tank with minimum pressure of 3.5 kg. / sq. cm. at terrace level or farthest point.

iii) One electric and one diesel pump of capacity 1620 LPM and One electric pump of capacity 180 LPM should be install.

iv) The pumps should be installed and arranged in such manner so that it will start automatically due to fall in pressure as prefixed in the installation by installing a Jockey pump. Provision of Jockey pump shall also be made to keep the water-based system under pressurized condition at all times.

v) All the pumps shall be so designed as to supply water at the designed pressure and discharge into the water-based system which shall be installed in the buildings.

#### DETECTION ALARM SYSTEM

Manually operated alarm system shall be installed for each floor, conforming is.I.S.2189-1988.

#### ALTERNATE POWER SUPPLY

Arrangement shall have to be made to supply of power with the help of generator to operate at least fire pump, illumination of staircase, corridors etc. and other places of assembly area in case of normal power failure.

HOSE REEL SYSTEM (IS 884:1985):-

i) Provision for Hose Reel in conjunction with wet riser shall be made at each floor of the building level from the underground reservoir through main pump conforming the relevant I.S. specification.

ii) The Hose reel hose system should be provided at each floor of the buildings. The internal dia of the said hose reel shall be 19 mm to 32 mm and the discharge capacity not less than 22.5 LPM. While the length of the hose reel not more than 36.50 meters. The distance of such installation should be in such a way that no part of the floor is more than 6 meters

distance from a hose nozzle when fully extended.

#### FIRST AID FIRE FIGHTING SYSTEM

First Aid Fire Fighting arrangement in the style of placing suitable type of portable fire extinguishers, fire buckets, etc. in all floors and vulnerable locations of the premises shall be made in accordance with I.S. 2190-1992.

#### GENERAL RECOMMENDATION

- 1.Fire notice for fire fighting and evacuation from the building shall be prepared and be displayed at all vulnerable place of the building as per clause 4.11 Annex D of N.B. Code.
- 2.Floor number and direction sign of escape shall be displayed prominently as per clause 4.11 Annex D of N.B. Code.
- 3.The employees and security staff shall be conversant with installed fire fighting equipment of the building on to operate in the event of fire and testing as per clause 4.11 Annex D of N.B. Code.
- 4.Arrangement shall be made for regular checking, testing and proper maintenance of all the fire safety installation and equipment installed in the building to keep them in perfectly good working conditions at all times.
- 5.Mock fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
- 6.Considering the gravity of growing hazard in the township, a crew of trained firemen under one experienced officer shall be maintained round the clock along with water tender (type-B) conforming I.S. 948 : 1983

Deputy Director  
West Bengal Fire & Emergency Services

Memo No.:FSR/012518622790045