



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Purulia Fire Station, Ranchi Road, Purulia, Pin:- 723101

Date : 03-06-2024

Memo No.: FSR/211862406300000829

From :
Divisional Fire Officer
Purulia Division
West Bengal Fire & Emergency Services

To :
Sanctuary Enclave
Rupchand Pandit Lane, Bhagabandh Para, P.S: Purulia Town, P.O& Dist: Purulia, Pin:723101

Sub: Fire Safety Recommendation for the occupancy of proposed construction of G+4 storied commercial (partly) cum residential apartment name and style "Sanctuary Enclave" under group Residential in favour of Proprietors Mr. Soumen Dutta for owners Sri Tara Sankar Chatterjee, Smt. Piyali Banerjee and Smt. Dolly Chatterjee, situated within Rupchand Pandit Lane, within Holding No: 116,117, Ward No: 12, under Purulia Municipality, Bhagabandh Para, R.S. Plot No: 11549/P, R.S. Khatian No: 2316, J.L. No: 292/2, Mouza: Purulia, P.O: Purulia, P.S: Purulia Town, Dist: Purulia, Pin: -723101..

This is in reference to your AIN 211862406300000829 dated 11-Apr-2024 regarding Fire Safety Recommendation for the occupancy of proposed construction of G+4 storied commercial (partly) cum residential apartment name and style "Sanctuary Enclave" under group Residential in favour of Proprietors Mr. Soumen Dutta for owners Sri Tara Sankar Chatterjee, Smt. Piyali Banerjee and Smt. Dolly Chatterjee, situated within Rupchand Pandit Lane, within Holding No: 116,117, Ward No: 12, under Purulia Municipality, Bhagabandh Para, R.S. Plot No: 11549/P, R.S. Khatian No: 2316, J.L. No: 292/2, Mouza: Purulia, P.O: Purulia, P.S: Purulia Town, Dist: Purulia, Pin: -723101.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this office is issuing Fire Safety Recommendation in favor of the aforesaid building for compliance of the following fire safety measure.

Recommendation :

A. CONSTRUCTION:

1. The whole construction of the building shall be carried out as per approved plan drawings conforming to the relevant building rules of the local Municipal Body. 2. The interior finish decoration of the building shall be made with materials with the low flame spread and low smoke and toxic gas generating categories

