



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:FSR/0125186231200336

Date: 19-06-2023

From:
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: M/S SQUAREMARK HOMES PRIVATE LIMITED

Holding No. 243 244, R.S. Dag no. 92, 93(P), 94, 95, 140, 141(P), 142(P), 143, 144(P), 145(P), 146, 147, 147/854, 148, 148/855, 149, 161, 165(P), Mouza- Sultanpur, PO - Mallickpur, Mallickpur Gram Panchayet, PS - Baruipur, Dist- South 24 Parganas, Pincode - 700145

Sub: Fire Safety Recommendation for proposed construction of Residential Complex comprising of 20nos. blocks of G+II storied under group of Residential Buildings in the name & style of "MOHORKOONJO" at Holding no. 243 & 244, R.S. Dag no. 92, 93(P), 94, 95, 140, 141(P), 142(P), 143, 144(P), 145(P), 146, 147, 147/854, 148, 148/855, 149, 161, 165(P), Mouza Sultanpur, P.O. Mallickpur, under Mallickpur Gram Panchayet, P.S. Baruipur, Dist. South 24 Parganas.

This is in reference to your application no. 0125186231200336 dated 15-05-2023 regarding the Fire Safety Recommendation for proposed construction of Residential Complex comprising of 20nos. blocks of G+II storied under group of Residential Buildings in the name & style of "MOHORKOONJO" at Holding no. 243 & 244, R.S. Dag no. 92, 93(P), 94, 95, 140, 141(P), 142(P), 143, 144(P), 145(P), 146, 147, 147/854, 148, 148/855, 149, 161, 165(P), Mouza Sultanpur, P.O. Mallickpur, under Mallickpur Gram Panchayet, P.S. Baruipur, Dist. South 24 Parganas.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this is issuing Fire Safety Recommendation in favor of the aforesaid building subject to the compliance of the following fire safety measure.

Recommendation:

A.CONSTRUCTION:

- 1.The whole construction of the proposed buildings shall be carried out as per approved plan drawings conforming the relevant building rules of local Municipal Body.
- 2.The interior finish decoration of the buildings shall be made of low flame spread materials conforming to I.S. specifications.
- 3.Provision of ventilation at the crown of the central core-duct of the buildings shall be provided.

B.OPEN SPACE & APPROACH:

- 1.The open spaces surrounding the buildings shall conform the relevant buildings rules as well as permit the accessibility and manoeuvrability of Fire Appliances with turning facility.
- 2.The approach road shall be sufficiently strong to withstand the load of Fire Engine weighting up to 45 M.T.
- 3.The width and height of the access gates into the premises shall not be less than 5.0 and 5.5 M respecting abutting the road.

C.STAIRCASE:

- 1.The staircase of the buildings shall be enclosed type. Entire construction shall be made of bricks / RCC type having Fire Resisting Capacity not less than 4 hours.
- 2.The staircase of the building shall have permanent vents at the top and open able sashes at each floor level in the external wall of the building.
- 3.The width of the Staircase shall have to be made as shown in the plan. Corridors and the exit doors shall conforming the relevant building rules.

D.FIRE FIGHTING WATER :

Under Ground Water Reservoir of 1,00,000 ltrs capacity exclusively for firefighting purpose with replenishing arrangements @1000 ltrs/min. preferably from two different sources of water shall have to be provided. The water reservoirs shall have overflow arrangement with the domestic water reservoir as well as to prevent stagnancy of water. The water reservoirs shall be kept full at all time.

E.WATER LAYOUT SYSTEM:

- 1.Yard Hydrant / Ring Main Hydrant with provision of adequate numbers of Pillar type Hydrant shall be installed in every 30mtr. surrounding the building in accordance with relevant I.S. specifications.
- 2.Provision for Hose Reel, Delivery hose and other necessary accessories in conjunction with Ring main shall be made near each Yard Hydrant points.
- 3.Provision of suitable Fire Service Inlet shall be made as per relevant I.S specification.

F.FIRE PUMP:

- i.Provision of the Fire Pump of 2850 LPM shall have to be made to supply water at the rate-designed pressure and discharge into the Water based system which shall be installed in the respective pump room.
- ii.One such pump shall always be kept on stand-by of 2850LPM preferably of diesel driven type.
- iii.Provision of Jockey Pump of 180 LPM shall also have to be made to keep the Water based suppression systems i.e. hydrant system under pressurized condition at all the time.

All the pumps shall be incorporated with both manual and auto starting facilities. The suction of pumps shall preferably of positive type or in case of negative suction the system shall be wet riser-cum-down comer with suitable terrace pump with overhead tank.

G.Electrical Installation & Distribution:

- 1.The electrical installation including transformers, Switch Gears, Main & Meters etc. and the distribution system of the premises shall be made satisfying the code of practice for Fire safety in general building as laid down in I.S. specification 1946 – 1982.
- 2.Electrical distribution system shall conform all the requirements as laid in I. S. 1646-1982.
- 3.The electrical installation shall be adequately protected with automatic CO2/D.C.P.
- 4.All electrical installation viz. Transformer Switch Gear L. T., H. T. rooms shall be protected with both auto detection and suppression systems as per suitability.

5. Alternative Power Supply :

Arrangements shall have to be made to supply power with the help of a generator to operate atleast the Fire Pumps, Pump for deep Tube-well, Fire Alarm System, lifts, etc. and also for illuminating the Staircase, corridors etc. and other places of assembly of the building incase of normal power failure.

H. Detection and Alarm System:

1. Manually operated Electrical Fire Alarm system with at least one number of break glass type call boxes fitted with Hooters shall be made in Control Room in the entire occupancy in each block. The Control Room shall be located at the entrance of Ground Floor of each block, other requirements of the system shall be made conforming I.S. 2189 – 1988.

I. FIRTAID FIRE FIGHTING SYSTEM:

First Aid fire fighting arrangement in the style of placing suitable type and sufficient numbers of portable Fire Extinguishers, Fire buckets etc in all floors and vulnerable locations in each blocks of the premises shall be made in accordance with I.S. 2190-92.

J. GENERAL RECOMMENDATIONS:

1. Driveway must be free from any kind of obstruction for ease movement of Fire Tenders.
2. Necessary sanction and approval for such construction and occupancy of this project must be obtained from competent authorities.
3. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.
4. Floor numbers and directional sign of escape route shall be displayed prominently.
5. The occupancy and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
6. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipments installed in the building to keep them in perfectly good working conditions at all times.
7. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
8. The certificate has to be obtained from the Director General, West Bengal Fire & Emergency Services certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements and installation of the building.

On compliance of all the above Fire and Life safety recommendations, the Director General, West Bengal Fire & Emergency Services shall be approached for necessary inspection and testing of the installation, Fire Safety Certificate in favour of the occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the building.

N.B. :Any deviation and changes the nature of use of the building in respect of the approved plan drawings, without obtaining prior permission from this office, this Fire Safety Recommendation will be treated as cancelled.

Director
West Bengal Fire & Emergency Services