



Speed Bdy.

भारतीय विमानपत्तन प्राधिकरण
AIRPORTS AUTHORITY OF INDIA

Date: 18.05.2011

File No. AAI/ER/NOC(103/11)/959-962,

NOC FOR HEIGHT CLEARANCE ONLY

To
Shri. Ricky Chandra & Shri. Vivek Ruia
21/2, Ballygunge Place
Kolkata - 700019

Sub: Issue of NOC

1. Please refer to your letter No.Nil dated 02.03.2011 on the subject mentioned above.
2. This office has no objection to the construction of the proposed Building by Shri. Ricky Chandra & Shri. Vivek Ruia here in after referred to as the applicant(s) at location Premises No.77, Ward No.82, Br.IX, P.S - Chetla, Peary Mohan Roy Road, Kolkata - 700027 to height of 45.20M (in figures) Forty Five decimal Two Zero Metres (in words) Above Ground Level. So that the top of the proposed structure when erected shall not exceed 10M (Site Elevation) plus(+) 45.20M height of the structure i.e. 55.20M (Fifty Five decimal Two Zero Metres) Above Mean Sea Level.
3. This No Objection Certificate is being issued on the express understanding that site elevation reduced level (height Above Mean Sea Level) is 10M of the relative location of the proposed building/structure & its distances and bearings from the ARP/Runway ends as tendered by the applicant(s) are correct. If however, at any stage it is established that the said data as tendered by the said applicant is actually different from actual data which could adversely affect aircraft operations, the structure or part(s) there of in respect of which this NOC is being issued will have to be demolished at his own cost or as may be directed by the A.A.I.. The applicant(s) is/are therefore advised in his/their own interest to verify the elevation and other data furnished for the site, before embarking on the proposed construction.
4. The issue of this NOC is further subject to the provisions of section 9-A of the Indian Aircraft Act 1934 and those of any notifications issued there under from time to time and under which the applicant may be called upon by the AAI to demolish in whole or in part the structure now being authorized vide this NOC.
5. No Radio/TV Antenna, lighting arresters, staircase, Mumtee, Overhead water tank and attachments or fixtures of any kind shall project above the restricted height indicated as in para 2.
6. The use of oil fired or electric fired furnace is obligatory within 08Km from the Airport.
7. This certificate is valid for a period of five years from the date of issue. If the building/structure/chimney is not constructed & completed within the above mentioned period of five years the applicant(s) required to obtain a fresh No Objection Certificate from the Chairman, Airports Authority Of India and /or the General manager (Aerodrome) E.R. The date of completion of building/structure/chimney should be intimated to the Chairman/or the General Manager (Aerodrome) Eastern Region.
8. No light or a combination of lights which by reason of its intensity, configuration or colour may cause confusion with the aeronautical ground lights of the nearby Airport shall be installed at the site at any time during or after the construction of the Building.

*** Day Marking & Night lighting with secondary power supply should be provided as per ICAO standard.
*** This NOC is subject to clearance from Airport Operator, if any Defence Airfield (or one for which AAI is not the aerodrome operator) is nearby.

for AIRPORTS AUTHORITY OF INDIA

Copy to:-

- 1) The General Manager (NOC), Airports Authority of India, New Delhi-110003 for information.
- 2) The Chairman, Br-IX, K.M.C, 37/1, Balaram Bose Ghat Road, Kolkata.
- 3) The Officer In-charge, Airports Authority of India, Civil Aerodrome, Kolkata.
- 4) Guard file.

महा प्रबंधक (एयरो)पूक्षे ने.सु.चं.बो हवाई अड्डा, कोलकाता - 700052
General Manager (Aero)ER N.S.C.B.I Airport, Kolkata - 700052

दूरभाष - 25119600
Phone - 25119600

