



Government Of West Bengal
Office Of The Deputy Director
West Bengal Fire & Emergency Services
Station Feeder Road, P.O & P.S Siliguri,
District: Darjeeling, Pin - 734005

Memo no.:FSR/0125186220400078

Date: 03-06-2022

From:
Deputy Director
North Zone, HQ Wing,
West Bengal Fire & Emergency Services

To: Residential Cum Commercial Building of Smt. Mousumi Saha and Others.
Nipendra Narayan Road, Holding No.: 205/3342, 206/3343, ,Kh. No.:1786,24986,24981,24982,24983,24984 L.R.,
Under Cooch Behar Municipality, Ward No.: 06, P.S.: Kotwali, Dist.: Cooch Behar.

Sub: Fire Safety Recommendation of Proposed construction of LG+UG+V storied Residential cum commercial Building under group of Business (Office) in the name of Smt. Mousumi Saha and Others. at the Premises no Nipendra Narayan Road, Holding No.: 205/3342, 206/3343, ,Kh. No.:1786,24986,24981,24982,24983,24984 L.R., Under Cooch Behar Municipality, Ward No.: 06, P.S.: Kotwali, Dist.: Cooch Behar. 736101

This is in reference to your application no. 0125186220400078 dated 22-05-2022 regarding the Fire Safety Recommendation of Proposed construction of LG+UG+V storied Residential cum commercial Building under group of Business (Office) in the name of Smt. Mousumi Saha and Others. at the Premises no Nipendra Narayan Road, Holding No.: 205/3342, 206/3343, ,Kh. No.:1786,24986,24981,24982,24983,24984 L.R., Under Cooch Behar Municipality, Ward No.: 06, P.S.: Kotwali, Dist.: Cooch Behar. 736101

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this is issuing Fire Safety Recommendation in favor of the aforesaid building subject to the compliance of the following fire safety measure.

Recommendation:
CONSTRUCTION

- 1.The whole construction of the proposed building shall be carried out as per approved plan drawing conforming relevant building rules of local administrative body (Municipal / panchayat).
- 2.The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specification.
- 3.Provision of ventilation at the crown of the central core-duct of the building shall be provided.
- 4.Arrangement shall have to be made for sealing all the vertical ducts by the materials of adequate fire resisting capacity.

OPEN SPACE & APPROACH

1. The open space surrounding the buildings shall conform the relevant building rules as well as permit the accessibility and manoeuvrability of fire appliances with turning facility having minimum 6.5 M width in each side.
2. The approach roads shall be sufficiently strong to withstand load of fire engine weighing up to 20 M.T.
3. The width and height of the access gates into the premises shall not be less than 4M and 5M respectively abutting the road.

In case of Air Condition (IS 659:1991):-

It shall conform to the following:-

- i) Escape routes like staircases, common corridors, lift lobbies etc. shall not be used as return air passages.
- ii) Regular check up of all split type window machine to prevent dust, foreign materials in the air inlet should maintained to prevent spontaneous combustion.
- iii) In case of central A.C. system, the same shall be incorporated with automatic dampers with fusible link with a View to shut down the system automatically in case of any fire in AC system.
- iv) Regular checking, testing, cleaning the Air inlet is must.
- v) Arrangements shall be made for isolation at the strategic locations by incorporating auto dampers in the Air Conditioning system.

STAIRCASE

- 1) The staircase of the building shall be enclosed type. Entire construction shall be made of bricks/R.C.C. type having fire resisting capacity not less than 4 hours.
- 2) The staircase of the building shall have permanent vents at the top and open able sashes at each floor level in the external wall of the building.
- 3) The width of the staircase shall be made as marked in the plan. Corridors and the exit doors shall conforming the relevant building rules which upto date amendment.
- 4) All the staircases shall be extended upto terrace of the building and shall be negotiable to each other without entering into any room.
- 5) Fire and smoke doors at the entrances of all the staircase enclosure as marked in the plan at each floor level shall be provided. The F.C.D. shall be of at least one hour fire resisting wire glass window fitted with self-closing type open able in the direction of escape.

LIFT

- 1) Walls of all lift enclosures shall have a fire rating of two hours; lifts shafts have a vent area not less than 0.2 M²
- 2) Lift Motor Room shall be located preferably on top of the shaft and separated from the shaft by the floor of the room.
- 3) Landing doors in all lift enclosures shall have a fire resistant of not less than half hour.
- 4) All Lift Car door shall have a fire resistance rating of half an hour.

5) Exit from the lift lobby, if located in the core of the building, shall be through a self closing smoke stop door of half an hour fire resistance.

6) Grounding Switch(es), at ground floor level shall be provided on all the lifts to enable the fire service to ground the lifts..

7) Fire Lift marked in the plan with the following specification – to enable fire services personnel to reach the upper floors with the minimum delay, and shall be available for the exclusive use of the firemen in an emergency.

8) The lift shall have a floor area of not less than 1.4 m². It shall have landing capacity of not less than 545 Kg (8 persons lift) with automatic closing doors of minimum 0.8 mm width.

9) In case of failure of normal electric supply, it shall automatically trip over to alternate supply. This changeover of supply could be done through manually operated changeover switch. Alternatively, the lift shall be so wired that in case of power failure, it comes down at the ground level and comes to stand still with door open.

FIRE FIGHTING WATER

The Centre shall have to be equipped with 100,000 lts. of underground stored water with replenishing arrangement @ 1000 lts./min preferably from two different sources of water supply.

Wet Riser System IS:3844

100mm dia riser with single out let landing valve shall have to be provided.

AUTOMATIC SPRINKLER SYSTEM

The automatic sprinkler system shall have to be installed in the entire commercial area.

Electrical Installation- shall be as per code of practice 1946: 1978, (NBC-Gr-iv) & Indian Electricity rules-1956 with up to date amendment. No electrical switch gear/ distribution should be installed below the staircase.

Pumps for fire fighting Installation (IS 12469:1988):-

i) The standard code of practice recommended that all water based fixed fire fighting installations should be fed by two separate automatic pumps, one of which should act as stand by. Each pump should be designed to deliver water at required pressure and discharge, taking into account the height and volume of the building.

ii) The Fire pumps should be provided near the underground static water storage tank with minimum pressure of 3.5 kg. / sq. cm. at terrace level or farthest point.

iii) One electric and one diesel pump of capacity 2280 LPM and One electric pump of capacity 180 LPM should be install.

iv) The pumps should be installed and arranged in such manner so that it will start automatically due to fall in pressure as prefixed in the installation by installing a Jockey pump. Provision of Jockey pump shall also be made to keep the water-based system under pressurized condition at all times.

v) All the pumps shall be so designed as to supply water at the designed pressure and discharge into the water-based system which shall be installed in the buildings.

vi) An independent identical pump for the purpose of sprinkler installation shall be made available. All such

arrangement shall be done as per above code of practice.

vii) All the pumps shall be incorporated with both manual and auto starting facilities .

DETECTION ALARM SYSTEM

Automatic detection and alarm system to be installed in the commercial area & Manual operated Electrical Fire alarm system shall be installed in the residential part of the building, which shall be made Conforming I.S. 2189-1988.

HOSE REEL SYSTEM (IS 884:1985):-

i) Provision for Hose Reel in conjunction with wet riser shall be made at each floor of the building level from the underground reservoir through main pump conforming the relevant I.S. specification.

ii) The Hose reel hose system should be provided at each floor of the buildings. The internal dia of the said hose reel shall be 19 mm to 32 mm and the discharge capacity not less than 22.5 LPM. While the length of the hose reel not more than 36.50 meters. The distance of such installation should be in such a way that no part of the floor is more than 6 meters distance from a hose nozzle when fully extended.

Yard Hydrants

Yard Hydrant IS 13039:2014 shall have to be installed.

ALTERNATE POWER SUPPLY

Arrangement shall have to be made to supply of power with the help of generator to operate at least fire pump, illumination of staircase, corridors etc. and other places of assembly area in case of normal power failure.

FIRST AID FIRE FIGHTING SYSTEM

First Aid Fire Fighting arrangement in the style of placing suitable type of portable fire extinguishers, fire buckets, etc. in all floors and vulnerable locations of the premises shall be made in accordance with I.S. 2190-1992.

GENERAL RECOMMENDATION

- 1.Fire notice for fire fighting and evacuation from the building shall be prepared and be displayed at all vulnerable place of the building as per clause 4.11 Annex D of N.B. Code.
- 2.Floor number and direction sign of escape shall be displayed prominently as per clause 4.11 Annex D of N.B. Code.
- 3.The employees and security staff shall be conversant with installed fire fighting equipment of the building on to operate in the event of fire and testing as per clause 4.11 Annex D of N.B. Code.
- 4.Arrangement shall be made for regular checking, testing and proper maintenance of all the fire safety installation and equipment installed in the building to keep them in perfectly good working conditions at all times.
- 5.Mock fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
- 6.Considering the gravity of growing hazard in the township, a crew of trained firemen under one experienced officer shall be maintained round the clock along with water tender (type-B) conforming I.S. 948 : 1983.

Validity unknown
Digitally signed by ABHIJIT
PANDEY
Date: 2022.06.03 18:00:27 IST

Deputy Director
West Bengal Fire & Emergency Services

0125186220400078