

GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D, MIRZA GHALIB STREET, KOLKATA- 700 016

Memo No.: WBFES/ 5147 /17/Kol-RB/101/04 (116/04)

Date: 17-07-17

From : Divisional Fire Officer
Fire Prevention Wing
West Bengal Fire & Emergency Services

To : Mr. R. S. Khetan
Director
DSK REAL ESTATES LIMITED
206, Acharya Jagadish Chandra Bose Road
7th floor, Unit No. - 7C
Kolkata - 700 017




Sub : Revised Fire Safety Recommendation for the proposed construction of
1 (One) no B+G+XXXXII storied Residential Building & 1 (One) no. Club
Building under group Residential Building, at the premises no. -
34, Diamond Harbour Road, Kolkata - 700 027, Ward No. - 79, Borough No. -
IX.

This is in reference to your letter no. - Nil Dated 03/07/2017 regarding Revised Fire Safety measure for the proposed construction of 1 (One) no B+G+XXXXII storied Residential Building & 1 (One) no. Club Building under group Residential Building, at the premises no. - 34, Diamond Harbour Road, Kolkata - 700 027, Ward No. - 79, Borough No. - IX.

The plan drawings submitted by you were scrutinized and marked as found necessary under the guidance of Technical expert Committee from Fire & Life Safety point of view. In returning one set of plan drawing with necessary marking, this office is issuing Revised Fire Safety Recommendation in favour of the aforesaid buildings subject to strict compliance of the earlier approved Recommendation as issued from this office vide memo no. - WBFES/4456/14/Kol-RB/101/04 (116/04) dated: 25/09/2014 with the following additional measures:

- I. Proper Traffic Signalling mechanism with alternate power supply to ensure that the wider portion of internal road towards Diamond Harbour Road can be used for parking of Fire Tenders to allow other Fire tenders to move in.
- II. Proper approach road from Remount Road for movement of Fire Tenders including Aerial Ladders shall be ensured prior to occupancy of the buildings.

However, necessary sanction & approval for such construction & occupancy must be obtained from competent authorities.


Divisional Fire Officer
Fire Prevention Wing
West Bengal Fire & Emergency Services