



Government Of West Bengal  
Office Of The Director General  
West Bengal Fire & Emergency Services  
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.: WBFES/5262/16/Kol-  
RB/876/16(876/16)

Date: 10-07-2021

**From:**  
Director  
Fire Prevention Wing,  
West Bengal Fire & Emergency Services

**To:** ALTAMIRA PROJECTS LLP  
67A/1, BALLYGUNGE CIRCULAR ROAD, WARD NO.- 69, BOROUGH NO.- VIII, KOLKATA - 700019

**Sub:** Revised Fire Safety Recommendation for addition & alteration of a proposal B+G+XIX storied Residential Building under group for the occupancy of Residential Building in the name & Style of "ALTAMIRA PROJECTS LLP" at the premises no.- 67A/1, BALLYGUNGE CIRCULAR ROAD, WARD NO.- 69, BOROUGH NO.- VIII, KOLKATA - 700019 under Kolkata Municipal Corporation, Kolkata.

This is in reference to your application no. 0125188218700100 dated 25-04-2021 regarding the Revised Fire Safety Recommendation for addition & alteration of a proposal B+G+XIX storied Residential Building under group for the occupancy of Residential Building in the name & Style of "ALTAMIRA PROJECTS LLP" at the premises no.- 67A/1, BALLYGUNGE CIRCULAR ROAD, WARD NO.- 69, BOROUGH NO.- VIII, KOLKATA - 700019 under Kolkata Municipal Corporation, Kolkata.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this office is issuing **Revised Fire Safety Recommendation** in favor of the aforesaid building subject to the compliance of the following fire safety measure.

**Recommendation:**

Sub : Revised Fire Safety Recommendation for addition & alteration of a proposal B+G+XIX storied Residential Building under group for the occupancy of Residential Building in the name & Style of "ALTAMIRA PROJECTS LLP" at the premises no.- 67A/1, BALLYGUNGE CIRCULAR ROAD, WARD NO.- 69, BOROUGH NO.- VIII, KOLKATA - 700019 under Kolkata Municipal Corporation, Kolkata.

This is in reference to your Application No. 0125188218700100 , dated 25/04/2021 , regarding the Fire Safety Measure for addition & alteration for Basement--- car parking area, filter tank, rainwater harvested tank, domestic & fire water, swimming pool , tank & pump & also some floor area specification on color coded plan drawing , Ground floor—Gate & Goomty , under ground water reservoir capacity, rainwater harvested tank ,domestic water & also some floor area specification on color coded plan drawing , 1st to 14th floor some area addition & alteration & lift area as per specification on color coded plan drawing , 15th floor to terrace stair has been stopped, the terminated stair



up to 15th floor to 19th floor staircase to terrace or roof level stair connected now ,& SOME AREA ARE ADDITION & ALTERATION specification on color coded plan drawing a proposal B+G+XIX storied Residential Building under group for the occupancy of Residential Building in the name & Style of "ALTAMIRA PROJECTS LLP" at the premises no.- 67A/1, BALLYGUNGE CIRCULAR ROAD, WARD NO.- 69, BOROUGH NO.- VIII, KOLKATA – 700019 under Kolkata Municipal Corporation, Kolkata.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety Point of view. In returning one set of plan with recommendation, this is issuing Revised Fire Safety Recommendation in favor of the aforesaid building subject to the compliance of the Following fire safety measure.

Recommendation:

Memo No : WBFES/5262/16 /KOL-RB/876/16(876/16) DATE: 08.08.2016. & Further APPLY

Revised Fire Safety Recommendation:

Memo No : AIN : 0125188218700100 , dated 25/04/2021 ,

1. The Fire Safety Recommendations which were issued from this department earlier vide memo no. Memo No : WBFES/5262/16 /KOL-RB/876/16(876/16) DATE: 08.08.2016. & Further apply

Revised Fire Recommendation:

Memo No : AIN : 0125188218700100 , dated 25/04/2021 ,respectively for now addition & alteration for Basement--- car parking area, filter tank, rainwater harvested tank, domestic & fire water, swimming pool , tank & pump & also some floor area specification on color coded plan drawing , Ground floor—Gate & Goomty , under ground water reservoir capacity, rainwater harvested tank ,domestic water & also some floor area specification on color coded plan drawing , 1st to 14th floor some area addition & alteration & lift area as per specification on color coded plan drawing , 15th floor to terrace stair has been stopped, the terminated stair up to 15th floor to 19th floor staircase to terrace or roof level stair connected now ,& SOME AREA ARE ADDITION & ALTERATION specification on color coded plan drawing a proposal B+G+XIX storied Residential Building under group for the occupancy of Residential Building in the name & Style of "ALTAMIRA PROJECTS LLP" at the premises no.- 67A/1, BALLYGUNGE CIRCULAR ROAD, WARD NO.- 69, BOROUGH NO.- VIII, KOLKATA – 700019 under Kolkata Municipal Corporation, Kolkata.

AS previous recommendation will remain Unchanged and strictly to be incorporated in this addition & alteration for proposal B+G+XIX storied Residential Building under group for the occupancy of Residential Building .

Fire Safety Certificate shall be obtained on compliance of all above Fire and Life safety Recommendations. The Director General, West Bengal Fire & Emergency Services shall be Approached for necessary inspection and testing of the installation. Fire Safety Certificate in favour of the occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the building.

N.B.: Any deviation and changes the nature of use of the building in respect of the approved plan drawing without obtaining prior permission from this office, this Fire and Life safety Recommendations will be treated as cancelled.



Signature valid

Digitally signed by ABHIJIT  
PANDEY  
Date: 2021.07.10 13:42:13 IST

Director  
West Bengal Fire & Emergency Services

Memorandum No. WBFES/5262/16/Ko-17B/876/16(876/16)