

GOVERNMENT OF WEST BENGAL  
OFFICE OF THE DIRECTOR GENERAL  
WEST BENGAL FIRE & EMERGENCY SERVICES  
13-D, Mirza Ghalib Street, Kolkata-16

Memo No. WBFES/ ৯৬৫ /14/24Pgs(N)RB/439/14(439/14)

Date- 8/5/14

From : Director-In-Charge, Fire Prevention Wing  
West Bengal Fire & Emergency Services  
13/D, Mirza Ghalib Street  
Kolkata - 16

To : Mr. Rajendra Kumar Agarwal  
Authorized Signatory  
Holding No-13, Netaji Subhas Road  
Ward No-26, P.S-Sonarpur  
Dist-24Pgs(S)


Sub : Fire Safety recommendation for Proposed construction of a G +VII storied under group Residential Building at Premises No. Holding No-13, Netaji Subhas Road, R.S.DagNo-38,43, Ward No-26, J.L.No-55, K.H.No-12,311, Mouza-Rajpur, P.S-Sonarpur, Dist-24Pgs(S) Under Rajpur Sonarpur Municipality.


This is in reference to your letter No Nil Dt 02.04.14 regarding Fire Safety measure for Proposed construction of a G +VII storied under group Residential Building at Premises No. Holding No-13, Netaji Subhas Road, R.S.DagNo-38,43, Ward No-26, J.L.No-55, K.H.No-12,311, Mouza-Rajpur, P.S-Sonarpur, Dist-24Pgs(S) Under Rajpur Sonarpur Municipality.

The plan drawings submitted by you was scrutinized and marked as found necessary from fire safety point of view. In returning one set of plan with recommendation, this office is issuing Fire Safety Recommendation in favour of the aforesaid building subject to the compliance of the following fire safety measure.

Encls:

1. One set of plan.
2. Recommendation Placed in this file.

  
Director-In-Charge  
(Fire Prevention Wing)  
West Bengal Fire & Emergency Services



(1)  
**RECOMMENDATION**

**A. CONSTRUCTION:**

1. The whole construction of the proposed building shall be carried out as per approval plan drawings conforming the relevant building rules of local Municipal Body(Bidhannagar/ Kolkata Municipal Corporation).
2. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specification.
3. Provision of ventilation at the central of the core-duct of building shall be provided.
4. Arrangements shall have to be made for sealing all the vertical ducts by the materials of adequate Fire resisting capacity.

**B. OPEN SPACE & APPROACH:**

1. The open space surrounding the building shall conform the relevant building rules as well as permit the accessibility and maneuverability of Fire appliance with turning facility.
2. The approach roads shall be sufficiently strong to withstand the load of Fire Engine weighting up to 45M.T.
3. The width and height of the access gates into the premises shall not be less than 4.5M and 5M respecting abutting the road.

**C. STAIR CASE:**

1. The staircase of the building shall be enclosed type. Entire construction shall be made of bricks/R.C.C. type having Fire resisting capacity not less than 4 hours.
2. The staircase of the building shall have permanent vents at the top and openable sashes at each floor level in the external wall of the building.
3. The width of the staircases shall be made as marked in the plan. Corridors and the exit door shall conforming the relevant building rules and well as rules of the cinematograph Act. With up to date amendments.
4. All the staircase shall be extended up to terrace of the building and shall be negotiable to each other without entering into any room.
5. Fire and smoke door at the entrance of all the Staircase enclosure as marked in the plan at each floor level shall be provided. The F.C.D. shall be of at least one hour Fire resisting wire glass window fitted with self-closing type open able in the direction of escape.

**D. LIFT:**


1. The walls of the lift enclosure shall be at least two hours Fire resisting type. Collapsible gate shall not be permitted.
2. One of the lift shall be designed for Fire Lift word "FIRE LIFT" shall conspicuously written at ground floor.

**E. FIRE FIGHTING WATER:**

Underground water reservoir having water capacity at 75,000Ltrs.and overhead reservoir of 5,000Ltrs. Capacity exclusively for Fire fighting purpose with replenishing arrangements @1,000Ltrs./min. Preferably from two different sources of water supply shall be provided. The Fire Water Reservoir shall have overflow arrangement with the domestic Water Reservoir as well as to avoid stagnancy of water. The water reservoir shall be kept full at all time.

**F. HYDRANT SYSTEM:**

- 1.The building shall be provided with Wet Riser of 150mm internal diameter pipe line with provision of landing valves at the Staircase landings/half landings at the rate of one such riser for 1,000sq.m.of floor area. The system shall be so designed that shall be kept charged with water all the time under pressure and capable to discharged 2,850 lts./min at the ground floor level outlet and minimum 900 lts./min at the top most outlet. In both cases the running pressure shall not be less that 3.5 kgs/Cm<sup>2</sup>. All other requirements shall conform I.S.3844-1989.





2. Provision for Hose Reel in conjunction with Wet Riser shall be made at each floor level. Conforming the relevant I.S. Specifications.
3. Provision of standard Hose Reel Hose supplied from the overhead reservoir through Booster Pump shall have to be made in all the floor of the building satisfy the code of I.S.3844-1989.
4. Yard Hydrant/Ring Main Hydrant with provision of adequate numbers Hydrant shall be installed surrounding the building in accordance with relevant I.S. specification.

#### **G. SPRINKLER INSTALLATION:**

The automatic Sprinkler installation shall be provided in Commercial Space area of the building as per I.S.9972. Alarm gang to be incorporated along with the sprinkler system.

#### **H. FIRE PUMP:**

Provision of Fire Pump shall have to be made to supply water at the rate-designed pressure and discharged into the water based system, which shall be installed in the building. One such pump shall always be kept on Stand-by preferable be of diesel driven type.

A separate Fire Pump shall preferably be made for the total Sprinkler Installation of the building. Provision of Jockey Pump shall also have to be made to keep the Water based system under pressurized condition at all the time. All the pumps shall be incorporated with both manual and auto starting facilities. The suction of pumps shall preferably of positive type or in case of negative suction the system shall be wet Riser-Cum-Down comer with suitable terrace pump with overhead tank.

#### **I. ELECTRICAL INSTALLATION & DISTRIBUTION:**

1. The electrical installation including transformer, switch gear, main & meters etc. and the distribution system of the premises shall be made satisfying the code of practice for Fire safety in general building as laid down in I.S. specification 1946-1982.

2. The vertical ducts shall be supply sealed at alternative floor level.

3. The electrical installation shall be adequately protected with CO2/D.C.P. or Medium Velocity/Projector System.

##### **4. Alternative Power Supply:**

Arrangements shall have to be supply power with the help of a generator to operate at least the Fire Pump, Pump for deep Tube-well, Fire Alarm System, Fire Lift etc. And also for illuminating the Staircase, corridors etc. and other places of assembly of the building incase of normal power failure.

#### **J. DETECTION ALARM AND SUPPRESSION SYSTEM:**

1. Manually operated Electrical Fire Alarm system with at least three numbers of break glass type call boxes fitted with Hooters along with public address system, talk back system at each floor connecting with audio-visual panel board be made in Control Room. The Control Room shall be located at the entrance of Ground Floor of the building, other requirements of the system shall be made conforming I.S.2189-1988.

2. Auto alarm detection system with the help of Flent and smoke detector shall be installed in all places below and preferably above false ceiling of the building. The system shall also be made in places of rooms where valuable articles have been kept. The other requirements of the system shall be made in accordance with I.S.2189-1988.

3. The suppression system shall be made with Fire Extinguisher and total flooding system with CO2/F.M-200 particularly in computer and Electrical processing and data room and in a room of irreplaceable articles.


4. Hooter will be sounded in such a manner so that an operation of a Detector or Manual Call Point Hooter will sounded on the same floor and immediate alternative floor.

##### **5. Public Address System:**

Public address system linked between all floor and Control Room shall have to be established.

#### **K. FIRST AID FIRE FIGHTING SYSTEM:**

First Aid Fire Fighting arrangement in the style of placing suitable type of portable Fire Extinguisher, Fire Buckets etc. in all floor and vulnerable locations of the premises shall be made in accordance with I.S.2190-1992.




**L. GENERAL RECOMMENDATIONS:**

1. Fire License shall have to be obtained for proposed storing and processing L.P.G. and other highly combustible articles.
2. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.
3. Floor numbers and directional sign of escape route shall be displayed prominently.
4. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
5. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire safety installation and equipments installed in the building to keep them in perfectly good working conditions at all times.
6. A crew of trained Fireman under the experienced Officer shall be maintained round the clock for safety of the building.
7. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
8. Each year a certificate is to be obtained from the **Director General, West Bengal Fire & Emergency Services** certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements and installation of the building.

On compliance of the above Fire and Life safety recommendations, the **Director General, West Bengal Fire & Emergency Services** shall be approached for necessary inspection and testing of the installation, Final N.O.C. in favour of the occupancy shall be issued on being satisfied with the test and performances of safety aspects of installation of the building.

**N.B.:** Any deviation and changes the nature of the building in respect of approved plan drawing, without obtaining prior permission from this office, this Fire & Life Safety recommendation will be treated as Cancelled.

  
**Director-In-Charge**  
**(Fire Prevention Wing)**  
**West Bengal Fire & Emergency Services**

