

GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D, Mirza Ghalib Street, Kolkata - 700 016

Memo No. : WBFES/ 7370 /17/Kol-BB/13/12 (13/12)

Date: 18.09.17

From : Divisional Fire Officer,
Fire Prevention Wing
West Bengal Fire & Emergency Services

To : The Authorised Signatory
Siddha Real Estate Development Pvt. Ltd.
Siddha Park, 99A, Park Street,
Kolkata - 700 016



Sub : Revised Fire Safety Recommendation for vertical extension 06 (Six) nos. floors over an existing construction B+G+XVIII storied i.e. B+G+XXIII storied Business Building & G+IV storied MLCP Block, at premises No.- 6, Jawarlal Nehru Road, Kolkata -700 013, Ward No. - 46, Borough -VI.

This is in reference to your letter No. - Nil dated 29/12/2016 regarding Revised Fire Safety measure for vertical extension 06 (Six) nos. floors over an existing construction B+G+XVIII storied i.e. B+G+XXIII storied Business Building & G+IV storied MLCP Block, at premises No.- 6, Jawarlal Nehru Road, Kolkata -700 013, Ward No. - 46, Borough -VI.

The revised plan drawing submitted by you was scrutinized and marked as found necessary from fire safety point of view. In returning one set of plan, this office is issuing Revised Fire Safety Recommendation in favour of the aforesaid building subject to the compliance of the following fire safety measure which was recommended from this office earlier vide memo No. - WBFES/367/12/Kol-BB/13/12 (13/12) dated 07/03/12 remain same & strictly to be followed except U.G.W.R. for fire 2, 00,000 Ltrs. and O.H.W.R. for fire 20,000 Ltrs.

Enclo. :

1. One set of plan.

DIVISIONAL FIRE OFFICER
FIRE PREVENTION WING
WEST BENGAL FIRE & EMERGENCY SERVICES