

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D Mirza Ghalib Street, Kolkata- 700 016**

Memo No : IND/WB/FES/20192020/65343

DATE: 11/12/2019

From :

The Director

Fire Prevention Wing,

West Bengal Fire & Emergency Services.

To :

Mr. Bodhan Majumdar

**7, Mujibar Rahaman Road, Dag No.-580, 1343 and 1344, Khatian No.-506, 456 and 98,
Mouza-Doharia, Ward No.-16, Madhyamgram Municipality, J.L.No.-45, R.S.No.-132,
Dist. North 24-Pgs., P.S.-Barasat, Kolkata- 700132.**

Barasat F.S., Barasat,

North 24 Parganas - 700132 .

**Sub :Fire safety Certificate for occupancy of B+G+X storied (Common basement)
comprising 3 nos of Residential block (A,B & C), under group Residential, at
premises no-7, Mujibar Rahaman Road, Dag No.-580, 1343 and 1344, Khatian No.-506,
456 and 98, Mouza-Doharia, Ward No.-16, Madhyamgram Municipality, J.L.No.-45,
R.S.No.-132, Dist. North 24-Pgs., P.S.-Barasat, Kolkata- 700132.**

.

This is in reference to your Application No. IND/WB/FES/20192020/65343,dated 11/12/2019, regarding the Fire safety Certificate for occupancy of B+G+X storied (Common basement) comprising 3 nos of Residential block (A,B & C), under group Residential, at premises no-7, Mujibar Rahaman Road, Dag No.-580, 1343 and 1344, Khatian No.-506, 456 and 98, Mouza-Doharia, Ward No.-16, Madhyamgram Municipality, J.L.No.-45, R.S.No.-132, Dist. North 24-Pgs., P.S.-Barasat, Kolkata- 700132.

.

.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing

the Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. Mechanical smoke extraction system shall have to be provided at basement area with adequate CFM.
2. Fire pumps & Detection system shall have to be kept always in auto mode condition.
3. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
4. The Interior finish decoration of buildings shall be made with low flame spread material confirming to the I.S. Specification.
5. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the buildings shall be strictly maintained.
6. Existing Electrical wiring of the whole buildings shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
7. The notice of Fire Fighting and Evacuation from the buildings shall be prepared and displayed at all vulnerable places of the Buildings.
8. The employees and security staff shall be conversant with installed fire fighting equipments of the buildings and to operate in the event of fire and testing.
9. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the buildings.
10. Transformer and switch gear shall be protected with CO2 or DCP Fire extinguishers confirming I.S. specifications.
11. First Aid fire fighting system shall be provided as per I.S. specifications.
12. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Buildings to keep them in perfectly good working condition at all the times.
13. If required the old electrical lines shall have to be replaced with new lines. The cables

shall always be laid in M.S. conduit pipes continuously bonded to the earth.

14.Periodical flashing of water in the Hydrants and Sprinklers pipe line shall be made to maintain the efficient working performance of above mentioned system.

15.Existing lift shall be treated as Fire Lift in case of emergency.

16.This Fire Safety Certificate is valid for three (3) years and has to be renewed every after three (3) years from the date of issue of this letter.

17.Every three (3) years a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the buildings.

Director
West Bengal Fire & Emergency Services