

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D Mirza Ghalib Street, Kolkata- 700 016**

Memo No : IND/WB/FES/20192020/60403

DATE: 19/09/2019

From :

The Director

Fire Prevention Wing,

West Bengal Fire & Emergency Services.

To :

PGE INFOSOLUTIONS PVT LTD AND OTHERS

183/1, KHAN ROAD, MOUZA- MANKUNDU, J.L. NO. 9, L.R. DAG NO. 898, 900.

Bhadreswar F.S., Bhadreswar,

Hooghly - 712139 .

Sub :Revised Fire Safety Recommendation for a proposed construction of 46 nos. G+II storied Row Housing (Bungalow) under group Residential Building in the name of 'PGE INFOSOLUTIONS PVT LTD AND OTHERS' at the premises no.- 183/1, KHAN ROAD, MOUZA- MANKUNDU, J.L. NO. 9, L.R. DAG NO. 898, 900., Bhadreswar, Hooghly - 712139.

This is in reference to your Application No. IND/WB/FES/20192020/60403,dated 19/09/2019, regarding the Fire Safety Measure for a proposed construction of 46 nos. G+II storied Row Housing (Bungalow) under group Residential Building in the name of 'PGE INFOSOLUTIONS PVT LTD AND OTHERS' at the premises no.- 183/1, KHAN ROAD, MOUZA- MANKUNDU, J.L. NO. 9, L.R. DAG NO. 898, 900., Bhadreswar, Hooghly - 712139..

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this is issuing Revised Fire Safety Recommendation in favour of the aforesaid building subject to the compliance of the following fire safety measure.

Recommendation:

1. Recommendations: -

- 1.The earlier Fire Safety Recommendation vide this office memo no. WBFES/Dy.DFS. W. Z/FP/245/2014/HOW/RB/970/14, Dated – 11.07.2014 strictly to be followed and to be maintained in good working condition.
- 2.The entire Row Housing (Bungalow) shall be covered by ground hydrant as per relevant I.S. specifications.
- 3.Manually operated Electrical Fire Alarm system with break glass type call boxes fitted with Hooters, at each floor connecting with audio-visual panel board shall be made in control room. The control room shall be located at the entrance of Ground Floor of the building.
- 4.First Aid Fire Fighting arrangement in the style of placing suitable Fire Extinguishers, Fire Buckets etc. in all floors and vulnerable of locations of the premises shall be made in accordance with I.S. 2190-1992.
- 5.The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
- 6.Arrangement shall be made for regular checking, testing and maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working condition at all times.
- 7.A crew of trained Fireman under the experienced Officer shall be maintained round the clock for safety of the occupants of entire proposed and existing building project.
- 8.Mock fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.

On compliance of all above Fire and Life safety recommendations, the Director General, West Bengal Fire & Emergency Services shall be approached for necessary inspection and testing of the installation, Fire Safety Certificate in favour of the occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the building.

N.B.:Any deviation and changes the nature of use of the building in respect of the approved plan drawing without obtaining prior permission from this office, this Revised Fire Safety Recommendation will be treated as cancelled.

Director
West Bengal Fire & Emergency Services