GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D, Mirza Galib Street, Kolkata – 700 016.

Memo. No.: WBFES/ 5011 /16   Ref-BB/96216 (96216) Date: 17/08/16

From : The Director in Charge
Fire Prevention Wing
West Bengal Fire & Emergency Services

To : The Director,
Vidhi Vyapaar Pvt. Ltd.
135, Cotton Street,
Kolkata-700 149.

Sub : Fire Safety Recommendation for Proposed construction of B+G+V Storied Office Building at premises No. – 76, Ulkalmoni Gopabandhu Sarani, Kolkata-700 007, Ward no-42.

This is in reference to your letter No. Nil dated 11.07.2016 regarding Fire Safety measure for Proposed construction of B+G+V Storied Office Building at premises No. – 76, Utkalmoni Gopabandhu Sarani, Kolkata-700 007, Ward no-42.

The plan drawing submitted by you was scrutinized and marked as found necessary from fire safety point of view. In returning one set of plan with recommendation, this office is issuing Fire Safety Recommendation in favour of the aforesaid building subject to the compliance of the following fire safety measures.

Enclo. :

1. One set of plan.
2. Recommendation placed in this file.

Director in Charge
Fire Prevention Wing
West Bengal Fire & Emergency Services

PARTY'S COPY

Plan for Water Supply arrangement including SEMILI G. & O. H. reservoirs should be submitted at the Office of the Ex-Engineer Water Supply and the sanction obtained before proceeding with the work of Water Supply any deviation may lead to disconnection/demolition.

Before starting any Construction the site must conform with the plans sanctioned and all theconditions as proposed in the plan should be fulfilled.
The validity of the written permission to execute the work is subject to the above conditions.

The sanction refers to the proposed portion shown in red and the Executive Engineers makes no admission as to the correctness of the plan.

THE KOLKATA MUNICIPAL CORPORATION
BUILDING PERMIT
No. 2017050121
Date 09-3-2018 Borough No. X
Ex. Engineer / Asst. Engineer
Bor. No. X Bor. No. X
★ BUILDING DEPARTMENT ★

Design of all Structural Members including that of the foundation should conform to Standards specified in the National Building Code of India

CONSTRUCTION SITE SHALL BE MAINTAINED TO PREVENT MOSQUITO BREEDING AS REQUIRED U/S 496 (1) & (2) OF CMC ACT 1980. IN SUCH MANNER SO THAT ALL WATER COLLECTION & PARTICULARLY LIFT WELLS, VATS, BASEMENT CURING SITES, OPEN RECEPTACLES ETC. MUST BE EMPITED COMPLETELY TWICE A WEEK.

Sanctioned subject to demolition of existing structure to provide open space as per plan before construction is started

Executive Engineer (C) BR. X   Asst. Engineer (C) Br. PLAN X

The building materials that will be stacked on Road/Passage or Foot-path beyond 3-months or after construction of G Floor, whichever is earlier may be seized forthwith by the K.M.C at the cost and risk of the owner.

No rain water pipe should be fixed or discharged on Road or Footpath.
Drainage plan should be submitted at the Borough Executive Engineer's Office and the sanction obtained before proceeding with the drainage work.

A suitable pump has to be provided i.e. pumping unfiltered water for the distribution to the flushing cisterns and urinals in the building incase unfiltered water from street main is not available.

Non Commencement of Erection/ Re-Erection within Two Year will Require Fresh Application for Sanction.

BUSINESS BUILDING

THE SANCTION IS VALIED UP TO 08-3-2023

DEVIATION WOULD MEAN DEMOLITION

Necessary steps should be taken for the safety of the lives of the adjoining public and private properties during construction.

As approved by Hon'ble Mayor & MPL Commissioner Meeting No- 540 dated 16-11-2017 vide Item No. 184-17-18

THE KOLKATA MUNICIPAL CORPORATION
RECEIVED
Date 9/3/18
Sig.
Borough No. IV & V
BUILDING DEPARTMENT