

Govt. of West Bengal
Fire Services
e-Challan Form

GRN: 19-201920-002525598-2
GRN Date: 14/06/2019 12:41:53

Payment Mode : Counter Payment
Bank : State Bank of India

DEPOSITOR'S DETAILS

Name : SMT PIU CHATTERJEE Id No. : IND/WB/FES/20192020/5
[REF No]
Contact No. Mobile No. +91 8101278308
E-mail : afsw101@rediffmail.com
Address : Regional Language
User Type :
Name : Director General

From Date : 14/06/2019 To Date : 14/06/2019

Address

Remarks : Fees under West Bengal Fire Services Act

PAYMENT DETAILS

Sl. No.	Identification No.	Head of A/C Description	Head of A/C	Amount[₹]
1	IND/WB/FES/20192020/53951	Fees Under West Bengal Fire Services Act- Service Fees	0070-60-109-001-14	184265
Total Amount				184265

In Words : Rupees One Lakh Eighty Four Thousand Two Hundred Sixty Five Only



Note: Produce this challan to any branch State Bank of India. Please ensure, to make your payment within 21/06/2019 (banking hours). This challan form shall be invalid after 21/06/2019

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES**

Memo No : IND/WB/FES/20192020/53951

DATE: 18/06/2019

From :

**The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.**

To :

**SMT PIU CHATTERJEE
PROPOSED G+3 STORIED COTTAGE TYPE RESIDENTIAL BUILDING OF SMT PIU
CHATTERJEE AT GOPALPUR ASANSOL ON R.S.PLOT NO.941,942,952,953, L.R.PLOT
NO.944,955,954,945, R.S.KH.NO.611,699,700,701,702,609,380,3
31,L.R.KH.NO.1074,MOUZAGOPALPUR,J.L.NO.10
Asansol F.S., Asansol PS (S),
Paschim Bardhaman - 713304 .**

**Sub :Fire Safety Recommendation for a proposed construction of G + 3 storied
building under group Residential at the premises no.- PROPOSED G+3 STORIED
COTTAGE TYPE RESIDENTIAL BUILDING OF SMT PIU CHATTERJEE AT GOPALPUR
ASANSOL ON R.S.PLOT NO.941,942,952,953, L.R.PLOT NO.944,955,954,945,
R.S.KH.NO.611,699,700,701,702,609,380,3
31,L.R.KH.NO.1074,MOUZAGOPALPUR,J.L.NO.10, Ps.Asansol(S),Dist. Paschim
Bardhaman PIN-713304**

This is in reference to your Application No. IND/WB/FES/20192020/53951, dated 18/06/2019, regarding the Fire Safety Measure for a proposed construction of G + 3 storied building under group Residential at the premises no.- PROPOSED G+3 STORIED COTTAGE TYPE RESIDENTIAL BUILDING OF SMT PIU CHATTERJEE AT GOPALPUR ASANSOL ON R.S.PLOT NO.941,942,952,953, L.R.PLOT NO.944,955,954,945, R.S.KH.NO.611,699,700,701,702,609,380,3 31,L.R.KH.NO.1074,MOUZAGOPALPUR,J.L.NO.10, Ps.Asansol(S),Dist. Paschim Bardhaman PIN-713304.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this is issuing Fire Safety

Recommendation in favour of the aforesaid building subject to the compliance of the following fire safety measure.

Recommendation:

- 1) The whole construction of the proposed G+3 Residential building shall be carried out/fulfil in accordance with the relevant building rule i.e NBC-IV and local authority.
- 2) The statutory open spaces surrounding the building as specified in National Building Code and local municipalities building rule and regulation, shall be free from any obstruction, projection etc and shall be open to sky at all times.
- 3) The interior finishing decoration like wall, ceiling shall be made with low flame spread materials confirming relevant IS specification.
- 4) Provision of ventilation at the central core-duct of the building shall be provided.
- 5) Arrangements shall have to be made for sealing all the vertical ducts by the materials of fire resisting capacity.
- 6) All electrical wiring shall be done in accordance with the National Electrical Codes.
- 7) The approach road shall be sufficiently strong to withstand the load of Fire engine weighing min. 20 M.T.
- 8) The width and height of the access gates into the premises shall not be less than 4.5 & 5 M. respectively.
- 9) At least 2(two) no's exists (min. Width 1.5m) or more in the form of door leading directly to the outside of the building or stairways shall be provided. All exits shall be free from obstruction.
- 10) 2(Two) no's enclosed type internal stair case having minimum Fire resisting capacity not less than 4 hrs., shall be provided as remote from each other as possible. The FCD at the entrance of the all stair cases as well as Lift lobby encloser having minimum Fire Resisting capacity shall be one hrs.
- 11) All internal stair case shall be extended from ground floor to terrace level except access to the basement shall be by a separate stair case. The slope of Ramp shall not exceed 1:10.
- 12) The wall of the lift enclose shall be at least 2hrs. Fire Resisting type. Collapsible gate shall not be permitted.
- 13) Opening in walls or floors, which are necessary to provided to allow passages of all building services like cables, electrical wirings, tele. Cables, plumbing pipes etc. Shall be protected by enclose in the form of ducts/shafts having a fire resistance not less than 2hrs. No gas piping, electrical panels shall be allowed in the stairway.
- 14) All landing of floor shall have floor indicating board as well as illuminated exit sign with arrow indicating way to the escape routes shall be provided at the suitable height from the floor level on the wall, which should comply with graphic requirements of the relevant Indian standard.

- 15) Staircase and Corridor lightning shall also be connected to alternative supply which may be provided battery continuously trickle charged from the electric main.
 - 16) Rooms containing inflammable or other service equipment subject to possible explosion shall not be located directly under or adjacent of the building.
 - 17) At least 5,000lts water capacity terrace level water reservoir for only Fire Fighting purpose with replenishing arrangement @1000lts/min. preferably from two different sources of water supply shall be provided for fire fighting purpose. One electric and one diesel pump of mini. Capacity 900LPM shall be provided to supply requisite water pressure not less than 2kg/cm² at terrace level.
 - 18) Provision of Hose Reel shall be arranged at each floor level, which shall be connected directly from the over head roof tank through automatically operated booster pump conforming the relevant IS specification. The length of the hose reel should be such that no part of the protected floor is more than 6m. away from the nozzle, at the time of fully extended.
 - 19) At least 2nos Water Co2/ 2nos ABC type, 2no Carbon dioxide type Fire Extinguisher, Fire bucket shall be installed in suitable places of each floor.
 - 20) Manually operated electrical fire alarm system, Smoke detector, Heat Detector shall be installed in the suitable place of floors.
 - 21) Alternative power supply with the help of Diesel Generator shall have to be made to provide power to Fire pump, escape lighting, fire alarm etc. in case of normal power supply failure.
 - 22) No storage or use of combustible materials of any kind shall be allowed in any part of the building except as necessary for day to day work.
 - 23) Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.
 - 24) A crew of trained fire fighting personnel shall be deployed round the clock.
 - 25) Mock drill shall be conducted time to time with all occupants of the building.
 - 26) Arrangement shall be made for regular checking, testing and proper maintenance of all the fire safety installation and equipments installed in the building to keep them in good working condition at all times.
 - 27) To eliminate fire hazards, good housekeeping, both inside and outside of the building, shall be strictly maintained regularly. Mock fire and evacuation drill shall be carried out periodically.
- Any deviation and changes the nature of the use of the building in respect of submitted plan drawing, without obtaining prior permission from the office, the FSR shall be treated cancelled.

Divisional Fire Officer

Sl. No. 1074/MOUZAGOPALPUR/J.L.NC
DATE: 18/06/2019

To: The Deputy Fire Officer,
P.O. No. 1074/MOUZAGOPALPUR/J.L.NC,
P.O. No. 1074/MOUZAGOPALPUR/J.L.NC,
P.O. No. 1074/MOUZAGOPALPUR/J.L.NC

Subject: Application for the issue of fire certificate for the
COTTAGE TYPE RESIDENCE INCLUDING OF 10 ROOMS
ASANSOL ON P.S. PLOT NO 941, 642, 892, 950, 951, 952, 953, 954,
R.S. NO. 311, 695, 700, 701, 702, 809, 327
J.L.NC NO. 1074/MOUZAGOPALPUR/J.L.NC

Reference: P.O. No. 1074/MOUZAGOPALPUR/J.L.NC
COTTAGE TYPE RESIDENCE INCLUDING OF 10 ROOMS
ASANSOL ON P.S. PLOT NO 941, 642, 892, 950, 951, 952, 953, 954,
R.S. NO. 311, 695, 700, 701, 702, 809, 327
J.L.NC NO. 1074/MOUZAGOPALPUR/J.L.NC

Signature valid
Digitally signed by NITAI
CHATTOPADHYAY
Date: 2019.06.18 13:01:55 IST