

GOVERNMENT OF WEST BENGAL
Office of the Director General
West Bengal Fire & Emergency Services
13-D Mirza Ghalib Street, Kolkata- 700 016

Memo No : IND/WB/FES/20172018/710

DATE: 21/09/2017

From :
The Director
Fire Prevention Wing
West Bengal Fire & Emergency Services.

To : GANGOTRI MARCOM PVT LTD & 8OTHS

Sub : Fire Safety Recommendation for Proposed Construction of: 19 Storied Building Under Group Building at the Premises No.- 5/1, NERODE BEHARI MULLICK ROAD, KOLKATA-700 0

This is in reference to your Application No. IND/WB/FES/20172018/710, dated 21/09/2017, regarding Fire Safety Measure for Proposed construction of 19 storied building under group building at the premises no.- 5/1, NERODE BEHARI MULLICK ROAD, KOLKATA-700 0

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this is issuing Fire Safety Recommendation in favour of the aforesaid building subject to the compliance of the following fire safety measure.

Recommendation:

1. CONSTRUCTION:

- 1.The whole construction of the proposed building shall be carried out as per approved plan drawings conforming the relevant building rules of local Municipality Body (Bidhannagar / Kolkata Municipal Corporation).
- 2.The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
- 3.Provision of ventilation at the crown of the central core-duct of the building shall be provided.

GANGOTRI DEALMARK PVT. LTD.
GANGOTRI MARCOM PVT. LTD.
GANPATI MARCOM PVT. LTD.
PUSPANJALI COMMERCIAL PVT. LTD.
RADHA KRISHNA MARCOM PVT. LTD.
SHUBH LABH MARCOM PVT. LTD.
TARAPITH COMMERCIAL PVT. LTD.
TARAPITH DISTRIBUTORS PVT. LTD.
TARAPITH MERCHANTS PVT. LTD.

Vivek Sany
DIRECTOR

GRAP REALTY PVT. LTD.

Jit Kumar Sany
DIRECTOR



Jit Kumar Sany