PARTY'S COPY

RESIDENTIAL BUILDING

No rain water pipe should be fixed or discharged on Road or Footpath. Drainage plan should be submitted at the Borough Executive Engineer's Office and the sanction obtained before proceeding with the drainage work.

A suitable pump has to be provided i.e. pumping unfiltered water for the distribution to the flushing cisterns and urinals in the building incase unfiltered water from street main is not available.

THE KOLKATA MUNICIPAL CORPORATION
BUILDING PERMIT
No. 2018060512
Date 8/1/19 Borough No.
Ex. Engineer / Asst. Engineer
Bor. No. Ber. No.
BUILDING DEPARTMENT

Plan for Water Supply arrangement including SEMILI G & O. H. reservoirs should be submitted at the Office of the Ex-Engineer Water Supply and the sanction obtained before proceeding with the work of Water Supply any beviation may lead to disconnection / demolition

THE SANCTION IS VALIED UP TO 27/02/2024.

CONSTRUCTION SITE SHALL BE MAINTAINED TO PREVENT MOSQUITO BREEDING AS REQUIRED U/S 466 (1) & (2) OF CMC ACT 1980, IN SUCH MANNER SO THAT ALL WATER COLLECTION & PARTICULARLY LIFT WELLS, VATS, BASEMENT CURING SITES, OPEN RECEPTACLES ETC. MUST BE EMPITED COMPLETELY TWICE A WEEK.

Before starting any Construction the site must conform with the plans sanctioned and all theconditions as proposed in the plan should be fulfilled.

The validity of the written permission to execute the work is subject to the above conditions.

The building materials that will be stacked on Road/Passage or Foot-path beyond 3-months or after construction of G. Floor, whichever is earlier may be seized forthwith by the K.M.C. at the cost and risk of the owner.

Necessary steps should be taken for the safety of the lives of the adjoining public and private properties during construction.

The sanction refers to the proposed portion shown in red and the Executive Engineers makes no admission as to the correctness of the plan.

Non Commencement of Erection/ Re-Erection within Two Year will Require Fresh Application for Sanction.

Splayed portion:- Sanctioned conditionally byundertaking of the owner that the splayed portionwill be free gifted to the K. M. C. and no wall can be constructed over it.

All Building Materials to necessary & construction should conform's to standered specified in the National Building Code of India.

Sanctioned subject to demolition of existing structure to provide open space as per plan before construction is started.

Approved By : MBL Meeting No. 30/8/18.
The Building Committee NO-551

8/1/19 Executive Engineer (C) BR.
Asst. Engineer (C) Dr. PLAN.

DEVIATION WOULD MEAN DEMOLITION

Green Building

Green Building Rating : Platinum
Certifying Authority : IGBC
Reference No. : NIL
Date : January 2018

GOVERNMENT OF WEST BENGAL
Office of the Dir...
West Bengal Fire & Emergency Services
13-D Mirza Ghalib Street, Kolkata- 700 016

Memo No.( )/WBF&ES/2017/2/49/18 DATED: 23/08/2017

From :
The Director,
Fire Prevention Wing,
West Bengal Fire & Emergency Services.

To
... CATEGORY/UNDER PVT/LTD SECTOR

Sub : Fire Safety Recommendation for Proposed Construction of 19 storied Building under group housing Block-Ten on Building at the Premises No.- 3/1, NERODE BEHARI MULLICK ROAD, KOLKATA-700 ...

This is in reference to your Application No. NOW/PRE/0017/2017(P), dated 31/08/2017, regarding the Safety Measures for Proposed Construction of 19 storied building under group housing Block-Ten on the premises No.- 3/1, NERODE BEHARI MULLICK ROAD, KOLKATA-700 ...

The plan etc. submitted by you are scrutinized and started as found necessary from Fire Safety point of view. In the matter, no objection/certificate is hereby granted to the proposed Building. But it is to be borne in mind that the aforesaid building subject to the compliance of the following conditions.

Yours faithfully,
...
DIRECTOR

The above mentioned plan of the proposed building position marked on the said approved plan do comply according the relevant building rules of local Municipality/ Fire Service Department and the following conditions.

1) The ... Fire Safety Measures of the building shall be made free access agreed mode for commencing fire operations.
2) Installation of certification of the system of the proposed ... shall be ... by the ... Division.
3) ...

...northern portion or other suitable means at the ... Left ... and one ... Northern side of the ... to ... Road.

... Underground water reservoir with water capacity of 100000 ltrs. ... over head water tank(s) with a total capacity of 20000 ltrs. ... for the purpose of ... and ... ensuring pressure of not less than ... 3.5 kg/sq.cm. ... preferably from two ... sources of water supply shall be provided. No water connection shall be taken from the underground water reservoir & pump set.

... Hose reel system shall be provided on each floor level and ... of the building.

... Automatic sprinkler system shall be provided in all floor areas of the building except ... Underground ... Ground ... Mezzanine ... Basement ... Lift machine room, Air conditioning plant room, ... Transformer room, Pump room, Meter room, Fire Control room, Fire Service Inlet room, Generator room, Switch gear room, Electrical duct