

GOVERNMENT OF WEST BENGAL

Office of the Deputy Director, West Zone

West Bengal Fire & Emergency Services

43D, G.T.Road, Howrah

Memo No : WBFES/DYDFS/WZ/FSR/1A/18
From: The Dy. Director(WZ)
West Bengal Fire & Emergency Services,
Howrah Division.

DATED: 26.09.2018



To: The Partners:

M/S Sahasini Developers

Ananda Gopal Maiti; S/O Late Anil Kumar Maiti, and Rajib Kumar Maiti, S/O Sri Ashok K. Maiti

Sub: Fire Safety Recommendation Against Existing The 9+0+ 10 Storied Building
(Institutional Occupancy) in the name of M/S Sahasini Developers, at Mouza - Karawicola,
J.L.No 171,CS Plot No - 48,RS Plot No 79, LR plot no 89,Holding no 1726/189/758, Ward No
22(Old,Old/new), Street - Burdighat, P.S Midnapur, Dist.Paschim Midnapur, Under Midnapur
Municipality.

Re: Your letter No Dated 14.9.2018

I have Returning Herewith a Copy of the plan duly signed and Approved by the Dept. You are
requested to comply the following Terms & Conditions as per IS 8044 NBC Part - II and West Bengal
Fire Services (Fire Prevent and Fire Safety)

Rules - 2004 along with the West Bengal Fire Services (Fire Utama) Rules - 2004.

RECOMMENDATION

A. Construction

1. The whole Construction of the existing building shall be carried out as per approved plan drawings
conforming the relevant Building rules of local Municipal body
2. Provision of verification at the crown of the central core-duct of the building shall be provided
3. Internal passage between the shop/market should be constructed in such a way that will be
at least 3 mtr.
4. Pump room shall be provided mark in to the plan drawings.


Sd/- Dy. Director
West Bengal Fire & Emergency Services