

GOVERNMENT OF WEST BENGAL  
OFFICE OF THE DIRECTOR GENERAL  
WEST BENGAL FIRE & EMERGENCY SERVICES  
13-D, Mirza Ghalib Street, Kolkata – 700 016.

Memo No. : WBFES/5631/13

/Kol-RB/1130/13(1130/13) Date: 10/10/13

From : Director,  
Fire Prevention Wing  
West Bengal Fire & Emergency Services

To : Mr. Nitin Bhimani  
Constituted Attorney of  
Mr.Chandan Chakraborty &Others,  
82,Sarat Bose Road, Front Block,  
Kolkata – 700 026

**Subject :** **Fire Safety Recommendation for Proposed construction of a G+XI storied under group Residential Building at premises no. – 86/1, P. Majumdar Road, Ward No.-106, Borough No.- XII, Kolkata-700 078.**

This is in reference to your letter No. – Nil dated 26.09.2013 regarding Fire Safety measure for Proposed construction of G+XI storied under group residential building at premises no. – 86/1, P. Majumdar Road, Ward No.-106, Borough No.-XII, Kolkata- 700 078.

The plan drawings submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this office is issuing **Fire Safety Recommendation** in favour of the aforesaid building subject to the compliance of the following fire safety measure.

**Encl. :**

1. One set of plan.
2. Recommendation.

  
10/10/13  
Director

Fire Prevention Wing  
West Bengal Fire & Emergency Services

## RECOMMENDATION

### **A. CONSTRUCTION :**

1. The whole construction of the proposed buildings shall be carried out as per approved plan drawings conforming the relevant buildings rules of The Kolkata Municipal Corporation.
2. The floor area exceeds 750 Sq.Mts. shall be suitably compartmented by separation walls up to ceiling level having at least two hours Fire resisting capacity.
3. The interior finish decoration of the buildings shall be made low flame spread materials conforming I.S. specifications.
4. Provision of ventilation at the crown of the central core-duct of the buildings shall be provided.
5. Arrangements shall have to be made for sealing all the vertical and horizontal ducts, shafts by the materials of adequate Fire resisting capacity.

### **B. OPEN SPACE & APPROACH :**


1. The open space surrounding the buildings shall conform the relevant buildings rules as well as permit the accessibility and maneuverability of Fire appliance with turning facility.
2. The approach roads shall be sufficiently strong to withstand the load of Fire Engine weighting up to 45 M.T.
3. The width and height of the access gates into the premises shall not be less than 4.5 Mts. and 5 Mts respecting abutting the road.

### **C. STAIRCASE :**

1. The staircase of the buildings shall be enclosed type. Entire construction shall be made of bricks/R.C.C. type having Fire resisting capacity not less than 4 hours.
2. The staircase of the buildings shall have permanent vents at the top and openable sashes at each floor level in the external wall of the buildings.
3. The width of the staircases shall be made as marked in the plan. Corridors and the exit doors shall conforming the relevant buildings rules with up to date amendment.
4. All the staircases shall be extended up to the terrace of the buildings and shall be negotiable to each other without entering into any room.
5. Fire and smoke doors at the entrances of all the staircase enclosures as marked in the plan at each floor level shall be provided. The F.C.D. shall be of at least one hour Fire resisting wire glass window fitted with self-closing type openable in the direction of escape.

### **D. LIFT :**

1. The walls of the lift enclosure shall be at least two hours Fire resisting type. Collapsible gate shall not be permitted.
2. One of the lift shall be designed as Fire Lift. The word "FIRE LIFT" shall conspicuously written in fluorescent paint on the lift landing doors at each floor level.



2. **REFUGE AREA** :

1. Refuge area is not less than 15sqm. Shall be provided on the external wall with cantilever projection or other suitable means at 24.9 mts.. levels of the building as shown in the drawing.
2. The refuge area shall be of Fire Resisting construction and protected with self closing F.C.D. at the entrance from the corridor or the staircase lobbies.
3. The position of Refuge areas shall be such that they are negotiable by the fire service ladder from the ground.

3. **HALL** :

1. The doors/aisles/gangway/cross gangways/sitting arrangements/corridors in hall etc shall be made as per good practice of N.B.C. part-IV fire protection

4. **FIRE FIGHTING WATER** :

Underground water reservoir having water capacity at 1,00,000Ltrs. and overhead reservoir of 10,000Ltrs. capacity exclusively for Fire Fighting purpose with replenishing arrangement @ 1000 Ltrs./Min. preferably from two different sources of water supply shall be provided. The Fire Water Reservoir shall have overflow arrangement with the domestic Water Reservoir as well as to avoid stagnancy of water. The water reservoir shall be kept full at all time.

5. **HYDRANT SYSTEM** :

1. The buildings shall be provided with Wet Riser of 150 mm internal diameter pipe line with provision of landing valves at the staircase landing/half landings at the rate of one such riser for 1000 Sq.Mt. of floor area. The system shall be so designed that be kept charged with Water all the time under pressure and capable to discharge 2850 Ltrs./Min. at the ground floor level outlet and minimum 900 Ltrs./Min. at the top most outlet. In both cases the running pressure shall not be less than 3.5 Kgs./Sq.cm. All other requirements shall conform I.S. 3844-1989.
2. Provision for Hose Reel in conjunction with Wet Riser shall be made at each floor level conforming the relevant I.S. specification.
3. Yard Hydrant/Ring Main Hydrant with provision of four numbers Hydrant with one number Fire Service inlet shall be installed surrounding the building in accordance with relevant I.S. specification.

6. **SPRINKLER INSTALLATION** :

The automatic Sprinkler installation shall be provided in car parking area and in first floor areas of the building as per I.S. 9972. Alarm gang to be incorporated along with the sprinkler system.

7. **FIRE PUMP** :

Provision of the Fire Pump shall have to be made to supply water at the rate-designed pressure and discharge into the water based system, which shall be installed in the buildings. One such pump shall always be kept on Stand-by preferably be of diesel driven type.

A separate fire pump shall preferably be made for the total Sprinkler installation of the buildings. Provision of Jockey Pump shall also have to be made to keep the Water based system under

pressurized condition at all the time. All the pumps shall be incorporated with both manual and auto starting facilities. The suction of pumps shall preferably of positive type or in case of negative suction the system shall be Wet Riser-cum-Down Comer with suitable terrace pump with overhead tank.

8. **ELECTRICAL INSTALLATION & DISTRIBUTION** :

1. The electrical installation including transformers, Switch Gears, Main & Meters etc. and the distribution system of the premises shall be made satisfying the code of practice for Fire Safety in general buildings as laid down in the I.S. specification 1946-1982.
2. The vertical ducts shall be supply sealed at alternative floor level.
3. The electrical installation shall be adequately protected with CO2/D.C.P. or Medium Velocity Projector System.
4. Alternative Power Supply :  
Arrangements shall have to be made to supply power with help of a generator to operate at least the Fire Pump, Pump for deep Tube-well, Fire Alarm System, Fire Lift, pressurization fans and blowers, smoke extraction and damper systems etc. and also for illuminating the Staircase, Corridors etc. and other places of assembly of the buildings incase of normal power failure.

9. **INTELLIGENCE ANALOGUE SYSTEM** :

1. Auto Fire Alarm System which analogue addressable smoke heat detectors as per suitability shall be installed in all floor area of the buildings.
2. Addressable analogue manual call boxes incorporating with sounders shall be installed in all the floor area of the buildings in such a manner that maximum travel distance shall not be more than 22.5m in order to reach any of the call point.
3. Micro Processor based fire alarm panel shall be installed and all shall also be connected with main panel at the Fire Control Room of the premises.
4. Both way Public address system linked between all floors and Control Room shall have to be established.
5. All the installation shall also satisfy the I.S. Specification 2189 as amended and the code of practice as laid down in N.B.C. pt. IV.

10. **AIR CONDITIONING SYSTEM** : ( if any )

1. The A.H.U. shall be separated for each floor with the system Air Ducts for individual floors.
2. Arrangement shall be made for isolation at the strategic locations by incorporating auto dampers in the Air Conditioning System.
3. The system of auto shut down of A.H.U. shall be incorporated with the auto detection and alarm system.
4. The Air Handling Units room shall not be used for storage of any combustible materials.

11. **FIRST AID FIRE FIGHTING SYSTEM** :

First Aid Fire Fighting arrangement in the style of placing suitable type of portable Fire



Extinguishers, Fire Buckets etc. in all floors including basements and vulnerable locations of the premises shall be made in accordance with I.S. 2190-1992.

12. **GENERAL RECOMMENDATIONS** :

1. Fire License shall have to be obtained for proposed storing and processing with L.P.G. and other highly combustible articles.
2. Fire Notice for Fire Fighting and evacuation from the buildings shall be prepared and be displayed at all vulnerable places of the buildings.
3. Floor numbers and directional sign of escape route shall be displayed prominently.
4. The employees and security staff shall be conversant with installed Fire Fighting equipments of the buildings and to operate in the event of Fire and Testing.
5. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipments installed in the buildings to keep them in perfectly good working conditions at all times.
6. A crew of trained Fireman under the experienced Officer shall be maintained round the clock for safety of the buildings.
7. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of the buildings.

Each year a certificate is to be obtained from the **Director General, West Bengal Fire & Emergency Services** certifying about the satisfactory services, performances of all Life and Fire Safety arrangements and installation of the buildings.

On compliance of all the above Fire and Life Safety recommendations, the **Director General, West Bengal Fire & Emergency Services** shall be approached for necessary inspection and testing of the installation; Final N.O.C. in favour of the occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the buildings.

**N.B. :** Any deviation and changes the nature of use of the buildings in respect of the approved plan drawing, without obtaining prior permission from this office, this Fire Safety Recommendation will be treated as cancelled.



*JCS/h*  
*10/10/13*

**DIRECTOR**  
**FIRE PREVENTION WING**  
**WEST BENGAL FIRE & EMERGENCY SERVICES**