## GOVERNMENT OF WEST BENGAL Office of the Director General West Bengal Fire & Emergency Services 13-D, Mirza Galib Street, Kolkata – 700 016.

Memo. No.: WBFES /4549 / 17 / Kol-RB/1272/13 (1272/13)

Date: 27 06-17

From:

**Divisional Fire officer** 

**Fire Prevention Wing** 

West Bengal Fire & Emergency Services.

To

The Partner,

Tirupati Properties,

9A/1, Umakanta Sen Lane,

Kolkata - 700 030.

Sub

Revised Fire Safety Recommendation for Proposed Addition & Alternation of Under Construction Two Blocks (G+XVII Storied Block-1 & G+XVI Storied Block-2) Under Group Residential Building at the Premises No.- 9A/1, Umakanta Sen Lane, Ward No.-004, Borough No.-I, P.S.-Chitpur, Kolkata-700 030.

This is in reference to your Letter No. Nil, Dated 24.05.2017, Regarding Revised Fire Safety Recommendation for Proposed Addition & Alternation of Under Construction Two Blocks (G+XVII Storied Block-1 & G+XVI Storied Block-2) Under Group Residential Building at the Premises No.- 9A/1, Umakanta Sen Lane, Ward No.-004, Borough No.-I, P.S.-Chitpur, Kolkata-700 030.

On considering your prayer for waiver, this office is issuing Revised Fire Safety Recommendation in favour of the aforesaid buildings subject to strict compliance of previous Fire Safety Recommendation as issued vide this office meme no.- WBFES/ 5345 / 15 /Kol-RB/1272/13 (1272/13) Dated-14.07.2015 & WBFES/ 5345 / 15 /Kol-RB/6441/16 (1272/13) Dated-12.09.2016 and the last approved plan drawings except the provision of said 9m x 15m area on driveway below each Fire Refuge Area. However minimum 6 mtr. wide clear driveway of load bearing capacity 45 M.T. shall be maintained surrounding the buildings for free movement with turning facility & operational use of Fire Service appliances including Aerial Ladder. Necessary sanction and approval for such construction and occupancy must be obtained from competent authorities.

## Enclose:

1. One No. of plan.

8

Emergency Service

Divisional Fire officer
Fire Prevention Wing
West Bengal Fire & Emergency Services