

GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D, Mirza Ghalib Street, Kolkata – 700 016.

Memo. No. : WBFES/5374 / 17 / Kol-BB / 799/14/ (799/14)

Date: 21-07-17

From : **Divisional Fire Officer**
Fire Prevention Wing
West Bengal Fire & Emergency Services.

To : **The Director,**
Madgul Developers Pvt. Ltd.
20, Ballygunge Circular Road,
Kolkata – 700 019.




Sub : **Revised Fire Safety Recommendation for Proposed Construction of B+G+XIII Storied Under Group Residential Building at the Premises No- 24, Diamond Harbour Road, Ward No.-144 and Borough No.-XIV Under KMC.**

This is in reference to your Letter No. Nil, Dated. 07.06.2017, regarding Revised Fire Safety Recommendation for Proposed Construction of B+G+XIII Storied Under Group Residential Building at the Premises No- 24, Diamond Harbour Road, Ward No.-144 and Borough No.-XIV Under KMC.

The revised plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan, this office has approved **Revised Plan Drawing** in favour of the aforesaid building subject to the compliance of the Fire Safety Measure and Sprinkler shall be provided Basement, Community Hall, Showroom, Office Area and as Recommendation issued earlier vide this office memo no. WBFES/6078/14/ Kol-BB / 799/14/ (799/14) Dated-08.12.14 remain same & shall strictly to be followed.

Enclose:

1. One set of plan.


Divisional Fire Officer
Fire Prevention Wing
West Bengal Fire & Emergency Services