

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D Mirza Ghalib Street, Kolkata- 700 016**

Memo No : IND/WB/FES/20182019/17465

DATE: 04/07/2018

From :

**The Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services.**

To :

**MONARK DEALCOM PRIVATE LIMITED
125 A MOTILAL NEHRU ROAD , WARD NO -85,BOROUGH NO - VIII,POLICE STATION -
LAKE, KOLKATA - 700029
Gariahat F.S., Lake,
Kolkata - 700029 .**

**Sub :Fire Safety Recommendations for the occupancy of a Proposed G+VII Storied
under group Residential Building situated at the premises No. 125 A Motilal Nehru
Road, Ward No -85 ,Borough No. - Viii, Police Station - Lake, Kolkata – 700029.**

This is in reference to your Application No. IND/WB/FES/20182019/17465,dated 04/07/2018,
regarding the Fire Safety Measures for the occupancy of a Proposed G+VII Storied under
group Residential Building situated at the premises No. 125 A Motilal Nehru Road, Ward No -
85 ,Borough No. - Viii, Police Station - Lake, Kolkata – 700029..

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety
point of view. In returning one set of plan with recommendation, this is issuing Fire Safety
Recommendation in favour of the aforesaid building subject to the compliance of the
following fire safety measure.

Recommendation:

1. 1.CONSTRUCTION:

a)The whole construction of the proposed building shall be carried out as per approved plan
drawings conforming the relevant building rules of local Municipal Body.

- b)The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
- c)Arrangements shall have to made for sealing all the vertical ducts by the materials of adequate Fire resisting capacity.

2.OPEN SPACE & APPROCH:

- a)The open space surrounding the building shall conform the relevant building rules.
- b)The approach roads shall be sufficiently strong to withstand the load of Fire Engine Weighting up to 45 M.T.
- c)The entrance and the exit gate shell have to be provided as per relevant building rules of the local municipal corporation and as show ad marked in the plan.

3.STAIRCASE :

- a)The Staircase of the building shall have permanent vents at the top and openable sashes at the each floor level in the external wall of the building.
- b)The width of the staircases shall be made as marked in the plan. Corridors and the exit doors shall conforming the relevant building rules with up-to-date amendments.
- c)The staircase shall be extended up to terrace of the building and shall be negotiable to each other without entering into any room.
- d)Fire and smoke doors at the entrances of all the staircase enclosures as marked in the plan at each floor level shall be provided. The F.C.D. shall be of at least two hour fire resisting wire glass window flitted with self-closing type open able in the direction of escape.

4.LIFT:

- a)The walls of the lift be enclosure shall be at least two hours Fire Resisting type.
- b)Collapsible gate shall not be permitted.
- c)The existing lifts will be treated as Fire Lift in case of emergency. The word "FIRE LIFT" shall conspicuously be written at ground floor.

5.FIRE FIGHTING WATER:

The underground reservoir of 50,00,000 Lts. capacity exclusively for Firefighting purpose with replenishing arrangements @ 1000 lts./min preferably from two different sources of water supply shall be provided. The Water Reservoir shall have overflow arrangement with the domestic Water Reservoir as well as to avoid stagnancy of water. The water reservoir shall be kept full at all time.

6.HYDRANT SYSTEM:

- a)The building shall be provided with Wet Riser at 100mm. internal diameter Pipe Line with provision of landing valves at the Staircase landings / half landings at the rate of one such riser for 1000 Sq.m. of floor area. The system shall be so designed that shall be kept charged

with Water all the time under pressure and capable to discharge 2280 lts/min. at the ground floor level outlet and minimum 900lts/min. at the top most outlet. In both cases the running pressure shall not be less than 3.5Kgs/Sq.cm. All other requirements shall conforming I.S. 3844 – 1989.

b) Provision for Hose Reel in conjunction with Wet Riser shall be made at each floor level. Conforming the relevant I. S. Specifications.

c) Yard Hydrant / Ring Main Hydrant with provision of four numbers Hydrant shall be installed surrounding the building in accordance with relevant I.S. specifications.

7. FIRE PUMP :

a) Provision of the Fire Pump shall have to be made to supply water at the rate-designed pressure and discharge into the water based system, which shall be installed in the building. One such pump shall always be kept on stand-by preferably be of diesel driven type.

b) Provision of Jockey Pump shall also have to be made to keep the Water based system under pressurized condition at all the time. All the pumps shall be incorporated with both manual and auto starting facilities. The suction of pumps shall preferably of positive type or in case of negative suction the system shall be wet riser-cum-down comer with suitable terrace pump with overhead tank. A separate pump for the sprinkler installation shall preferably be provided.

8. ELECTRICAL INSTALLATION & DISTRIBUTION:

a) The electrical installation including transformers, Switch Gears, Main & Meters etc. and the distribution system of the premises shall be made satisfying the code of practice for Fire Safety in general building as laid down in I.S specification 1946-1982.

b) The vertical and horizontal electrical sealed at each floor level by fire resisting material.

c) The electrical installation shall be adequately protected with CO₂/D.C.P.

d) Alternate Power Supply:

Arrangements shall have to be made to supply power with the help of a generator to operate at least the Fire Pump, Pump for deep Tube-well, Fire Alarm System, etc. and also for illuminating the Staircase, corridors etc. and other places of assembly of the building in case of normal power failure.

9. DETECTION AND ALARM SYSTEM :

Manually operated Electrical Fire Alarm system with at least three numbers of break glass type call boxes fitted with Hooters along with public address system, at each floor connecting

with visual panel board shall be made in Control Room. The Control Room shall be located at the entrance of Ground Floor of the building, other requirements of the system shall be made conforming I.S. 2189 – 1988.

10. FIRST AID FIRE FIGHTING SYSTEM:

First Aid Fire fighting arrangement in the style of placing suitable type of portable Fire Extinguishers, Fire Buckets etc. in all floors and vulnerable locations of the premises shall be made in accordance with I.S. 2190-1992.

11. GENERAL RECOMMENDATIONS:

- a) Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.
- b) Floor numbers and directional sign of escape route shall be displayed prominently.
- c) The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
- d) Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipments installed in the building to keep them in perfectly good working conditions at all times.
- e) Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
- f) Each year a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services certifying about the satisfactory services, performance of all the Life & Fire Safety arrangements and installation of the building.
- g) On compliance of all the above Fire and Life safety recommendations, the Director General, West Bengal Fire & Emergency Services shall be approached for necessary inspection and testing of the installation, Fire Safety Certificate in favour of the occupancy shall be issued on being satisfied with the tests and performances of safety aspects of installation of the building.
- h) N.B: Any deviation and changes the nature of use of the building in respect of the approved plan drawing, without obtaining prior permission from this office, this Fire Safety Recommendation will be treated as cancelled.

Validity unknown
Digitally signed by ABHIJIT
PANDEY
Date: 2018.07.04 12:16:03 IST

Director
West Bengal Fire & Emergency Services