

Point No. 09

The following is the summary of the development works of the proposed facilities to be provided for the proposed project.

Fire- Fighting

The buildings are provided with Fire- Fighting facilities in adherence to NBC -2016 and West Bengal Fire and Emergency Department as below-

1. An underground tank of 100kl capacity has been provided.
2. Overhead tanks of 25kl in each Cluster have been provided.
3. System of wet riser cum downcomer is provided.
4. F.H.Cs are placed at suitable distances.
5. External fire hydrants have been provided.
6. Ensuring the movement of Fire tender around all the buildings.

Drinking Water

1. Domestic water tanks of capacity of 25kl in Cluster-1, 30kl in Cluster-2 and 20kl in Cluster-3 are provided with suitable filtration/treatment. The extent of filtration will be governed by the quality of water as/water test report.
2. Individual ROs can be provided to each flat.

Emergency Evacuation Services

1. Suitable numbers of fire staircases have been provided with fire doors in each cluster so that people can easily evacuate in case of fire/other emergency.
2. All the staircases open up at stilt floor level.

Use of Renewable Energy

1. The concerned project is of affordable segment and the initial cost of tapping renewable energy is quite high. Because of this, renewable energy is not being used.

Gangadhar Infracon Pvt. Ltd

Ranjana Aggarwal

Director