

GOVERNMENT OF WEST BENGAL
Office of the Director General
West Bengal Fire & Emergency Services
13-D, Mirza Ghalib Street, Kolkata - 700 016

Memo No.: WBFES/ **6330** /17 /24PGS(S)/RB/309/07 (314/07) Date: **21.08.17**

From : Divisional Fire Officer
Fire Prevention Wing
West Bengal Fire & Emergency Services

To : The Director
Greenfield City Project LLP
Srijan House,
36/1A, Elgin Road
Kolkata: 700 020



Subject: Revised Fire Safety Recommendation for proposed vertical extension of one floor over G+XI storied Residential Buildings comprising Block-A (Tower Nos. 36 to 41), Block-B (Tower Nos. 28 & 29) and Block-C (Tower Nos. 30 to 35) at premises No. E3/398, Jote Shibrapore, Ward No. 14, Maheshtala Municipality, 24PGS (S).

This is in reference to your letter No: Nil dt.12.05.17 regarding the Revised Fire Safety measures for proposed vertical extension of one floor over G+XI storied Residential Buildings comprising Block-A (Tower Nos. 36 to 41), Block-B (Tower Nos. 28 & 29) and Block-C (Tower Nos. 30 to 35) at premises No. E3/398, Jote Shibrapore, Ward No. 14, Maheshtala Municipality, 24PGS (S).

The revised plan drawings submitted by you were scrutinized and marked as found necessary from fire safety point of view. In returning one set of plan this office is issuing Revised Fire Safety Recommendation and instructed to follow strictly the earlier Recommendation issued vide this office Memo No: WBFES/7621/08/ 24PGS(S)/RB/309/07 (314/07) Dated 11.01.08.

In addition, minimum 05 mtrs driveway surrounding the buildings shall have to be provided and auto detection and suppression system shall have to be provided in community halls.

Encl. :

1. One set of plan .


DIVISIONAL FIRE OFFICER
FIRE PREVENTION WING
WEST BENGAL FIRE&EMERGENCY SERVICES