

GOVERNMENT OF WEST BENGAL  
DIRECTORATE OF ELECTRICITY

1, HARISH MUKHERJEE ROAD, KOLKATA - 700 020.

\*\*\*\*\*

No. ACM/ 1541, Dated, Kolkata, the 02-07-2012

From :: The Dy. Chief Electrical Inspector, Govt. of West Bengal.

To :: M/s. Oriental Sales Agencies India Pvt. Ltd.  
2, Jessore Road, Kolkata - 700 028.

Approval for your 11KV outdoor type compact sub-station comprising of 1 - 1000KVA, 11KV/433Volts, 3-phase, 50HZ Dry Type Transformer, Type: Dyn 11 bearing Sl. No. ILYDIN-110220001 Make - ABB Ltd and 1-630Amp, 11KV switchgear, Type - CV bearing Sl. No. IVYN040 112020241, Make - ABB Ltd for construction purpose only.

at your above site as desired

in your Ref. No. Nil dated 24.05.2012.


Dear Sir/s,

With reference to your application under rule 63(2) of the Indian Electricity Rules, 1956 and the inspection by the office on 19.06.2012 I hereby accord approval to your bringing into use the high voltage installation mentioned above subject to your compliance with the requirements of the Indian Electricity Rules, 1956 as set out below and any future additions to or alterations in the 11KV high voltage circuits or apparatus being notified to the Electrical Inspector, West Bengal and approval in writing obtained from him before the same are brought into use.

\* you are required make a fench of 5 feet high around the CSS Keeping required clearance and put up "Danger Board" on the fench at the front side within a week on consideration of safety.

Encl : A Bill for Rs. 1580.00/- only.

Yours faithfully,



( A. C. MANDÁL )

DY. CHIEF ELECTRICAL INSPECTOR,  
WEST BENGAL