

GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D, Mirza Ghalib Street, Kolkata-700016.

Memo No. : WBFS / 7748 / 17 / Kol- RB cum HB-Club / 566 /10 (575 /10)

Date : 10.10.17

From :
Divisional Fire Officer
Fire Prevention Wing
West Bengal Fire & Emergency Services



To :
The Director
Oriental Sales Agencies India Pvt. Ltd.
687, Anandapur, EM Bypass
Kolkata-700107.

Sub: Revised Fire Safety Recommendation of B+G+XIII storied Residential buildings comprising #Block-A1-A6, #Block-B1-B5, #Block-C1-C8, #Block-D1,D2, #Block-E1,E2, 1 no B+G+II storied Club building attached with D2 (all are upon a common Basement) and B+G+XII storied Mixed Occupancy building at 2, Jessore Road, PS-Dum Dum Under South Dum Dum Municipality, Dist-24 Pgs(N).

This is in reference to your letter, received on 04.08.2017 regarding Revised Fire Safety Recommendation of B+G+XIII storied Residential buildings comprising #Block-A1-A6, #Block-B1-B5, #Block-C1-C8, #Block-D1,D2, #Block-E1,E2, 1 no B+G+II storied Club building attached with D2 (all are upon a common Basement) and B+G+XII storied Mixed Occupancy building at 2, Jessore Road, PS-Dum Dum Under South Dum Dum Municipality, Dist-24 Pgs(N).

The revised plan drawings submitted by you was scrutinised and marked as found necessary from fire safety point of view. In returning one set of revised plan with Recommendation, this office is issuing **Revised Fire Safety Recommendation** in favour of the aforesaid building subject to the compliance of the following fire safety measures.

The earlier issued Fire Safety Recommendation vide this office Memo No: WBFS/ 1671 /12/ Kol-RB/ 421/12 (421/12) date: 19.07.12 shall have to be followed strictly & additionally

- Alternative staircase of 2 Mtr. flight shall have to be provided from Basement to Ground in the Mixed Occupancy building.
- Refuge Area of B+G+XII storied Mixed occupancy building will be provided at the half landing in between 6th & 7th floor and 9th & 10th floor instead of 8th & 10th floor level.
- The Lifts which are terminating at basement level shall have to be of "Pressurised Type".

Enclo:

- 1) One set of plan


10/10/17
DIVISIONAL FIRE OFFICER
FIRE PREVENTION WING
WEST BENGAL FIRE & EMERGENCY SERVICES