

**GOVERNMENT OF WEST BENGAL**  
**Office of the Director General**  
**West Bengal Fire & Emergency Services**  
**13-D, Mirza Ghalib Street, Kolkata - 700 016.**

**Memo. No. : WBFES/** / **Kol/RB/1775/12 (1775/12)** **Date:**

**From :** **Deputy Director (Headquarter)**  
**West Bengal Fire & Emergency Services**

**To :** Mrs. V.N. Rathi,  
Director,  
Orbit Victoria Grihanirman Pvt. Ltd.  
1, Garstin Place,  
Kolkata - 700001

**Subject :** Revised Fire Safety Recommendation for proposed construction of B+G+XVI storied Residential Building at premises no. 30, Shekespeare Sarani, ward no- 63, Borough - VII, Kolkata - 700017.

This is in reference to your letter No: Nil dt. 27.02.18 regarding the Revised Fire Safety Recommendation for proposed construction of B+G+XVI storied Residential Building at premises no. 30, Shekespeare Sarani, ward no- 63, Borough - VII, Kolkata - 700017.

The revised plan drawing submitted by you was scrutinized and marked as found necessary from fire safety point of view. In returning one set of plan with recommendation, this office is issuing **Revised Fire Safety Recommendation** in favour of the aforesaid building subject to the compliance of the earlier Fire Safety Recommendation issued Vide this office memo no. WBFES/5256/14/kol-rb/1775/12 (1775/12) dt. 11.11.14 shall have to be followed strictly & additionally.

- Refuge area shall have to be provided at 27.05 mtr, 41.05 mtr, and 55.05 mtr level respectively.

**Encl. :**

1. One set of plan

  
**Deputy Director (Headquarter)**  
**West Bengal Fire & Emergency Services**