



TO WHOM IT MAY CONCERN

We do hereby declare that in respect of our Project NEER for which registration is being sought under WBHIRA fire safety measures as per the NOC provided by the Fire Department shall be installed. Copy of NOC received from Fire Department is attached along with summary safety measures being installed.

Dated: 29th May 2019

Place: Kolkata

For Modello Ventures LLP
For Modello Ventures LLP

NKLL
Designated Partner
Designated Partner



GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D, Mirza Galib Street, Kolkata – 700 016.

Memo. No. : WBFES/ 7692/11 /24Pgs(S)-RB/973/10(993/10) Date : 24/2/11

From : **Director General,**
West Bengal Fire & Emergency Services.

To : Ledo Financial Services Ltd & Others,
3B, Lalbazar Street, 3RD Floor,
Kolkata-700 001.

Sub : **Provisional N.O.C. for proposed construction of 3 Blocks of B+G+XVI, B+G+XVII & G+XV storied under group Residential Building at premises No.- Mouza-Kumrakhali, J.L.No.-48, H.No.-266, P.S.Sonarpur, Dist.-24Pgs(S), Ward No.-25, Kolkata-700 103.**

This is in reference to your letter No.-Nil dated 21.10.2010 regarding Provisional N.O.C. of fire safety measure for proposed construction of 3 Blocks of B+G+XVI, B+G+XVII & G+XV storied under group Residential Building at premises No.- Mouza-Kumrakhali, J.L.No.-48, H.No.-266, P.S.Sonarpur, Dist.-24Pgs(S), Ward No.-25, Kolkata-700 103.

The plans submitted by you were scrutinized and marked as found necessary from fire safety point of view. In returning one set of plan with recommendation, this office is issuing **Provisional N.O.C.** in favour of the aforesaid building subject to the compliance of the following fire safety measures.

Enclo. :

1. One set of plan.
2. Recommendation.

Amun / Amun
23/2/11
✓ **DIRECTOR GENERAL**

WEST BENGAL FIRE & EMERGENCY SERVICES

FIRE-FIGHTING ARRANGEMENT

- Fire fighting arrangement has been considered as per the fire norms.
- Dedicated water storage facility has been considered for fire fighting arrangement.
- Sprinkler arrangement at each floor with fire alarm has also been considered as per the norms.
- Fire escape, fire refuge area has been incorporated in the building design as per the rule. Secondary staircases for every building block has been provided.
- Emergency assembly at ground level has also been earmarked.
- During operational phase trained facility management team will conduct mock drill in regular interval.
- Training to the facility management staff on fire fighting system will be conducted in regular basis.



