

GOVERNMENT OF WEST BENGAL  
OFFICE OF THE DIRECTOR GENERAL  
WEST BENGAL FIRE & EMERGENCY SERVICES  
13-D, Mirza Galib Street, Kolkata – 700 016.

Memo. No. : WBFES/7408/16 /Kol-RB/1225/14 (1225/14) Date : 16.11.16

From : The Director in Charge,  
Fire Prevention Wing,  
West Bengal Fire & Emergency Services.

To : Mr. Surendra Kumar Dugar,  
PS Group Reality Limited & Others,  
48, Matheswartola Road,  
Kolkata-700 046.



Sub : Fire Safety Recommendation for Proposed two floor over B+G+XXXI storied, i.e. B+G+XXXIII storied & one new block B+G+XXXV storied under Group Residential Building at premises no-48, Matheswartola Road, Kolkata-700 046.


This is in reference to your letter No. Nil dated 03.08.2016 regarding Fire Safety Recommendation for Proposed two floor over B+G+XXXI storied, i.e. B+G+XXXIII storied & one new block B+G+XXXV storied under Group Residential Building at premises no-48, Matheswartola Road, Kolkata-700 046.

The revised plan submitted by you was scrutinized and marked as found necessary from fire safety point of view. In returning one set of plan, this office has approved **Revised Plan Drawing** in favour of the aforesaid building subject to the compliance of the fire safety measure as recommendation issued earlier vide this office memo no.-WBFES/3105/15/Kol-RB/1225/14 (1225/14) dt.-28/11/14 remain same & strictly to be followed.

- 1) Fire Refuge area mention new Block at 26.4m, 42.9m, 59.4m, 75.9m, 92.4m, 109.1mtr level.
- 2) Overhead water reservoir having capacity 25,000 Ltrs in each tower.

Enclo. :

1. One set of plan.

  
Director in Charge  
Fire Prevention Wing

WEST BENGAL FIRE & EMERGENCY SERVICES