



NOTE :

1. DISTANCE BETWEEN 2 SPRINKLER 3m.
2. DISTANCE BETWEEN 2 SMOKE DETECTOR 36 m.
3. 2 NOS. FILE ALARM USE PER FLOOR
4. DISTANCE BETWEEN 2 HYDRANT VALVE 30 m.

PROJECT

PROPOSED (G+VII) STORIED RESIDENTIAL BUILDING PLAN AT 1411 GARIA STATION ROAD, P.S.-GARIA, DIST. - 24PGS(S) KOLKATA-700084

DOOR & WINDOW SCHEDULE

TYPE	SIZE	SILL	SIZE
W1	1500x1200	F/D	2100x2100
W2	1200x1200	D1	1200x2100
W3	1000x1050	D2	1050x2100
W4	600x600	D3	600x2100

LEGENDS:

	FIRE ALARM
	SMOKE DETECTOR
	SPRINKLER
	HOSE REEL
	HYDRANT VALVE
	PORTABLE FIRE EXTINGUISHER
	FIRE BUCKET
	100 mm. Ø HYDRANT PIPE
	25 mm. Ø HYDRANT PIPE
	ELECTRICAL CABLE

NOTES

1. ALL DIMENTION ARE IN MM.
2. ALL EXTERNAL WALLS ARE 200 mm. THK. & INTERNAL WALLS ARE 125 mm. THK.
3. ALL SORTS OF PRECAUTIONARY MEASURE WILL BE TAKEN FROM CONSULTANT'S F.S.R. DRAWING
4. SOME MEASUREMENT ARE ASSUMED.

CLIENT
INDICON ESTATES PVT. LTD.

TITLE
1ST FLOOR PLAN FOR FIRE SYSTEM

DWG. NO.
FS-03

REVISION

SCALE: 1:100
DRAWN BY: S.K.J.
DATE: 05.06.2015



CLIENT'S SIGNATURE

Drawing prepared by:-

M T ENTERPRISE
CONTRACTOR OF FIRE SAFETY APPLIANCES & SUPPLIER OF FIRE SAFETY EQUIPMENTS & SYSTEMS
E-mail ID - mtenterprise2fire@gmail.com

1ST FLOOR FIRE SYSTEM PLAN