



NOTE :
 1. DISTANCE BETWEEN 2 SPRINKLER 3m.
 2. DISTANCE BETWEEN 2 SMOKE DETECTOR 36 m.
 3. 2 NOS. FILE ALARM USE PER FLOOR
 4. DISTANCE BETWEEN 2 HYDRANT VALVE 30 m.

PROJECT
PROPOSED (G+VII) STORIED
RESIDENTIAL BUILDING PLAN AT
1411 GARIA STATION ROAD,
P.S.-GARIA, DIST. - 24PGS(S)
KOLKATA-700084

DOOR & WINDOW SCHEDULE

TYPE	SIZE	SILL	SIZE
W1	1500x1200	F/D	2100x2100
W2	1200x1200	D1	1200x2100
W3	1000x1050	D2	1050x2100
W4	600x600	D3	800x2100

LEGENDS:

[Symbol]	FIRE ALARM
[Symbol]	SMOKE DETECTOR
[Symbol]	SPRINKLER
[Symbol]	HOSE REEL
[Symbol]	HYDRANT VALVE
[Symbol]	PORTABLE FIRE EXTINGUISHER
[Symbol]	FIRE BUCKET
[Symbol]	100 mm. Ø HYDRANT PIPE
[Symbol]	25 mm. Ø HYDRANT PIPE
[Symbol]	ELECTRICAL CABLE

NOTES
 1. ALL DIMENSION ARE IN MM.
 2. ALL EXTERNAL WALLS ARE 200 mm. THK. & INTERNAL WALLS ARE 125 mm. THK.
 3. ALL SORTS OF PRECAUTIONARY MEASURE WILL BE TAKEN FROM CONSULTANT'S F.S.R. DRAWING
 4. SOME MEASUREMENT ARE ASSUMED.

CLIENT
INDICON ESTATES PVT. LTD.

TITLE
2ND FLOOR PLAN FOR FIRE SYSTEM

DWG. NO.
FS-04

REVISION

SCALE: 1:100
DRAWN BY: -S.K.J.
DATE: 05.06.2015

NORTH
 N

CLIENT'S SIGNATURE

Drawing prepared by-
MT ENTERPRISE
 CONTRACTOR OF FIRE SAFETY APPLIANCES &
 SUPPLIER OF FIRE SAFETY EQUIPMENTS & SYSTEMS
 E-mail ID - mtenpresearch2fire@gmail.com

2ND FLOOR FIRE SYSTEM PLAN