



NOTE :
 1. DISTANCE BETWEEN 2 SPRINKLER 3m.
 2. DISTANCE BETWEEN 2 SMOKE DETECTOR 36 m.
 3. 2 NOS. FIRE ALARM USE PER FLOOR
 4. DISTANCE BETWEEN 2 HYDRANT VALVE 30 m

PROJECT
 PROPOSED (G+VII) STOREIED
 RESIDENTIAL BUILDING PLAN AT
 1411 GARIA STATION ROAD,
 P.S.-GARIA, DIST. - 24PG(S)
 KOLKATA-700084

DOOR & WINDOW SCHEDULE

TYPE	SIZE	SILL	SIZE
W1	1500x1200	F/D	2100x2100
W2	1200x1200	D1	1200x2100
W3	1000x1050	D2	1050x2100
W4	600x800	D3	800x2100

LEGENDS:

☰	FIRE ALARM
⊕	SMOKE DETECTOR
⊙	SPRINKLER
⊗	HOSE REEL
⊠	HYDRANT VALVE
⊔	PORTABLE FIRE EXTINGUISHER
A	FIRE BUCKET
=====	100 mm. Ø HYDRANT PIPE
===== ===== =====	150 mm. Ø HYDRANT PIPE
-----	25 mm. Ø HYDRANT PIPE
-----	ELECTRICAL CABLE

NOTES
 1. ALL DIMENTION ARE IN MM.
 2. ALL EXTERNAL WALLS ARE 200 mm. THK. & INTERNAL WALLS ARE 125 mm. THK.
 3. ALL SORTS OF PRECAUTIONARY MEASURE WILL BE TAKEN FROM CONSULTANT'S F.S.R. DRAWING
 4. SOME MEASUREMENT ARE ASSUMED.

CLIENT INDICON ESTATES PVT. LTD.	
TITLE BASEMENT PLAN FOR FIRE SYSTEM	
DWG. NO. FS-01	
REVISION	
SCALE: 1:100 DRAWN BY: S.K.J. DATE: 05.06.2015	
CLIENT'S SIGNATURE:	

Drawing prepared by-
M T ENTERPRISE
 CONTRACTOR OF FIRE SAFETY APPLIANCES &
 SUPPLIER OF FIRE SAFETY EQUIPMENTS & SYSTEMS
 E-mail ID - mten@priserach2fire@gmail.com

BASEMENT FLOOR FIRE SYSTEM PLAN