



**NOTE :**  
 1. DISTANCE BETWEEN 2 SPRINKLER 3m.  
 2. DISTANCE BETWEEN 2 SMOKE DETECTOR 36 m.  
 3. 2 NOS. FILE ALARM USE PER FLOOR  
 4. DISTANCE BETWEEN 2 HYDRANT VALVE 30 m.

**PROJECT**  
**PROPOSED (G+VII) STORED RESIDENTIAL BUILDING PLAN AT 1411 GARIA STATION ROAD, P.S.-GARIA, DIST. - 24PGS(S) KOLKATA-700084**

**DOOR & WINDOW SCHEDULE**

TYPE	SIZE	SILL	SIZE
W1	1500x1200	F/D	2100x2100
W2	1200x1200	D1	1200x2100
W3	1000x1050	D2	1050x2100
W4	600x600	D3	800x2100

**LEGENDS:**

	FIRE ALARM
	SMOKE DETECTOR
	SPRINKLER
	HOSE REEL
	HYDRANT VALVE
	PORTABLE FIRE EXTINGUISHER
	FIRE BUCKET
	100 mm. Ø HYDRANT PIPE
	25 mm. Ø HYDRANT PIPE
	ELECTRICAL CABLE

**NOTES**  
 1. ALL DIMENSION ARE IN MM.  
 2. ALL EXTERNAL WALLS ARE 200 mm. THK. & INTERNAL WALLS ARE 125 mm. THK.  
 3. ALL SORTS OF PRECAUTIONARY MEASURE WILL BE TAKEN FROM CONSULTANT'S F.S.R. DRAWING  
 4. SOME MEASUREMENT ARE ASSUMED.

**CLIENT**  
 INDICON ESTATES PVT. LTD.  
**TITLE**  
 3RD & TYPICAL FLOOR PLAN FOR FIRE SYSTEM  
**DWG. NO.**  
 FS-05  
**REVISION**  
 SCALE: 1:100  
 DRAWN BY- S.K.J.  
 DATE: 05.06.2015  
**CLIENT'S SIGNATURE**

**Drawing prepared by-**  
**M T ENTERPRISE**  
 CONTRACTOR OF FIRE SAFETY APPLIANCES & SUPPLIER OF FIRE SAFETY EQUIPMENTS & SYSTEMS  
 E-mail ID - mtenterprise@rediffmail.com

**TYPICAL FLOOR FIRE SYSTEM PLAN**