

**GOVERNMENT OF WEST BENGAL  
OFFICE OF THE DIVISIONAL FIRE OFFICER  
WEST BENGAL FIRE & EMERGENCY SERVICES**

Memo No : IND/WB/FES/20192020/52076

DATE: 27/05/2019

**From :**

**The Divisional Fire Officer  
Fire Prevention Wing,  
West Bengal Fire & Emergency Services.**

**To :**

**PROPOSED G 7 STORIED APARTMENT BUILDING OF NABAUDYOG ENTERPRISE AT  
ARRAH PS-KANSA DIST-PASCHIM BARDHAMAN PIN-713148  
PROPOSED G 7 STD APARTMENT BLDG OF NABAUDYOG ENTERPRISE OVER RS  
PLOT NO-2063,2064,,2065,2066,2067,2068(P),  
MOUZA-ARRAH,JL NO-91,KH NO-4514,4515,4516,406,  
4508,4509,4510,191,4511,4512,4513,1461,4549,4548,PS-KANKSA,DIST-PASCHIM  
BARDHAMAN,PIN-713148  
Durgapur F.S., Kanksa PS,  
Paschim Bardhaman - 713148 .**

**Sub :Fire Safety Recommendation for a proposed construction of G + 7 storied  
building under group Residential at the premises no.- PROPOSED G 7 STD  
APARTMENT BLDG OF NABAUDYOG ENTERPRISE OVER RS PLOT NO-  
2063,2064,,2065,2066,2067,2068(P),  
MOUZA-ARRAH,JL NO-91,KH NO-4514,4515,4516,406,  
4508,4509,4510,191,4511,4512,4513,1461,4549,4548,PS-KANKSA,DIST-PASCHIM  
BARDHAMAN,PIN-713148, Kanksa PS, Paschim Bardhaman - 713148**

This is in reference to your Application No. IND/WB/FES/20192020/52076,dated 27/05/2019,  
regarding the Fire Safety Measure for a proposed construction of G + 7 storied building  
under group Residential at the premises no.- PROPOSED G 7 STD APARTMENT BLDG OF  
NABAUDYOG ENTERPRISE OVER RS PLOT NO-2063,2064,,2065,2066,2067,2068(P),  
MOUZA-ARRAH,JL NO-91,KH NO-4514,4515,4516,406,  
4508,4509,4510,191,4511,4512,4513,1461,4549,4548,PS-KANKSA,DIST-PASCHIM  
BARDHAMAN,PIN-713148, Kanksa PS, Paschim Bardhaman - 713148.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety

made in accordance with I.S. 2190-1992.

**N.GENERAL RECOMMENDATIONS :**

- 1) Fire License shall have to be obtained for proposed storing and processing with L.P.G. and other highly combustible articles.
  - 2) Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the Building.
  - 3) Floor numbers and directional sign of escape route shall be displayed prominently.
  - 4) The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
  - 5) Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipments installed in the building to keep them in perfectly good working conditions at all times.
  - 6) A crew of trained fireman under and experienced officer shall be maintained round the clock for safety of the building.
  - 7) Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
  - 8) Each year a certificate is to be obtained from the Divisional officer, Birbhum Division. West Bengal Fire & Emg. Services certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements and installation of the building.
  - 9) This Fire Safety Recommendations valid for one Year from the Date of Issue and Prior information is required for further extension the period.
- 

**Divisional Fire Officer  
West Bengal Fire & Emergency Services**

Signature Not Verified  
Digitally signed by NITAI  
CHATTOPADHYAY  
Date: 2019.05.27 13:06:33 IST