



CIN No : U45309WB2017PTC220329

Corporate Address :

81, Golaghata, VIP Road, 1st floor, Radhakunj Apartment,
Near Bika Banquet, Kolkata - 700048

I Phone : 033 6501 5151 | Web : www.evanieinfra.com

I Email : info@evanieinfra.com

Ref. No. :EIPL/19/HIRA/Legal/03005

Date: 02.04.2019

DECLARATION

Apropos the observation sent by the HIRA authority regarding the project named **Nature City (Phase 1)** on 'Emergency Evacuation Facilities', a declaration from the designated Architect of the Project i.e. M/S Prakalpa Space Kraft Pvt. Ltd. is attached herewith as **Annexure A** for consideration.

EVANIE INFRASTRUCTURE PVT. LTD.

.....**Director**

Supriya Kumar Patra

Director



PRAKALPA® SPACE KRAFT PRIVATE LIMITED

ARCHITECTURE | INTERIOR | PLANNING | DESIGN

CIN : U70109WB2012PTC182021

GSTIN : 19AAGCP6685H1ZT


PROPOSED G+4 STORIED RESIDENTIAL COMPLEX ATR.S DAG.NO. - 3884
& 3885 , MOUZA- BISHNUPUR, J.L.NO - 44 ,R.S KHATIAN .NO.- 126,L.R
KHATIAN .NO.- 8606, P.S. -RAJARHAT UNDER CHANDPUR GRAM
PANCHAYAT, DIST.- 24 PARGANAS(N)

EMERGENCY EVACUATION SYSTEM

Here in this project for each block we are having 4 tenements in each floor catered by 1 stair almost equidistance from each of the tenement which is about 1.5 Mtr. from the main entrance door and around 6 Mtr. from the furthest end of the tenement.

Hence we have proposed this staircase for the first way of emergency exit. Apart from this each floor will have a fire extinguisher of ABC type and a Ring Main Hydrant system all around the site.

In connection to this we are having a proper driveway of 4Mt. within the site for the movement of emergency vehicle at any time.


ATANU CHAKRABORTY
Chartered Architect
CA/99/24684

.....
Signature of Architect
AtanuChakraborty.
(CA/99/24684)

AN ISO 9001 : 2008 COMPANY

145, Nanigopal Roy Chowdhury Avenue, (CIT Road), Entally, Mezzanine, 2nd, 3rd & 4th Floor, Kolkata - 700 014
Phone : 033 2265 0612, E-mail : prakalpa.arch@gmail.com, Website : www.prakalpa.in