

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES**

Memo No : IND/WB/FES/20182019/45703

DATE: 19/03/2019

From :

**The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.**

To :

**DURGAPUR NABAUDYOG DEVELOPERS
RS Plot No-1586, LR Plot No-2023,2024, Kh.No-1292, JL No-91, Mouza-Arrah
Durgapur F.S., Durgapur PS,
Paschim Bardhaman - 713212 .**

Sub :Fire Safety Recommendation for a proposed construction of G + 6 storied building under group Residential at the premises no.- RS Plot No-1586, LR Plot No-2023,2024, Kh.No-1292, JL No-91, Mouza-Arrah, Durgapur PS, Paschim Bardhaman - 713212

This is in reference to your Application No. IND/WB/FES/20182019/45703, dated 19/03/2019, regarding the Fire Safety Measure for a proposed construction of G + 6 storied building under group Residential at the premises no.- RS Plot No-1586, LR Plot No-2023,2024, Kh.No-1292, JL No-91, Mouza-Arrah, Durgapur PS, Paschim Bardhaman - 713212.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this is issuing Fire Safety Recommendation in favour of the aforesaid building subject to the compliance of the following fire safety measure.

Recommendation:

1. The whole construction of the proposed building shall be carried out as per approved plan drawings conforming the relevant building rules of local Municipal Body.
2. The floor area exceeds 750m² shall be suitable compartmented by separation wall up to ceiling level having at least two hours Fire resisting capacity.

3. The interior finish decoration of the building shall be made low flame spread materials conforming I.S specifications,
4. Provision of ventilation at the crown of the central core- duct of the building shall be provided.
5. Arrangement shall have to be made for sealing all the vertical ducts by the materials of adequate Fire resisting capacity.
6. The open space surrounding the building shall conform the relevant building rules as well as permit the accessibility and maneuverability of Fire appliance with turning facility.
7. The approach roads shall be sufficiently strong to with stand the loan of Fire Engine weighting up to 20 M.T.
8. The width and height of the access gates into the premises shall not be less than 4.5-5 M respecting abutting the road,
9. The staircase of the building shall be enclosed type. Entire construction shall be made of bricks / R.C.C .type having Fire resisting capacity not less than 4 hours.
10. The staircase of the building shall have permanent vents at the top and open able sashes at each floor level in the external wall of the building.
11. All the staircase shall be extended up to terrace of the building and shall be negotiable to each other without entering into any room.
12. Fire and smoke doors at the entrances of the Staircase enclosures as marked in the plan at each floor level shall be provided. The F.C.D. shall be of at least one hour Fire. Resisting wire glass window fitted with self- closing type open able in the direction of escape.
13. Overhead reservoir of 5,000 lts/min. preferably from two different sources of water supply shall be provided. The water reservoir shall have overflow arrangement with the domestic water reservoir as well as to avoid stagnancy of water. The water reservoir shall be kept full at all time.
14. The building shall be provided with down corner of 100mm internal diameter pipe line with provision of landing valves at the Staircase landings/half landings at the rate of one such riser for 1000 Sq m of floor area.
15. Provision for Hose Reel in conjunction with down comer shall be made at each floor level conforming the relevant I.S. Specifications Provision for down comer shall be made at each floor level. Conforming the relevant I.S Specifications.
16. One main fire pump and one standby pump, preferably diesel driven, of capacity minimum 1850 LPM and head of the pump will be such that 3.5 Kg/cm² pressure is available at the furthest/highest landing valve to be installed. Auto start facility should be incorporated in fire pump. Accordingly, Jokey pump of capacity 180LPM shall also be installed, conforming to the norms of National Building Code part-IV- fire and life safety.
17. The Electrical installation including transformers. Switch Gears, Main & Meters etc. and the distribution system of the premises shall be made satisfying the code of practice for Fire safety in general building as laid down in I.S. specification 1946-1982.
18. The vertical ducts shall be supply sealed at alternative floor level.

19. Arrangement shall have to be made to supply power with the help of a generator to operator at least the /fire Pump for deep Tube-well, Fire Alarm System, Fire Lift etc. and also for illuminating the Staircase, corridors etc. and other places of the building in case of normal power failure.

20. Manually operated Electrical Fire Alarm system with at least three numbers of break glass type call boxes fitted with Hooters along with public address system, talk back system at each floor connecting with audio- visual panel board shall be made in Control Room. The Control Room shall be located at the entrance of Ground Floor of the building, other requirements of the system shall be made conforming I.S. 2189-1988.

21. Public address system linked between all floors and Control Room shall have to be established.

22. The A.H.U shall be separated for each floor with the system Air Ducts for individual floors.

23. Arrangement shall be made for isolation the strategic locations by incorporating auto dampers in the Air Conditioning system.

24. The system of auto shut down of A.H.U shall be incorporated with the auto detection and alarm system.

25. The air handling units room shall not be used for storage of any combustible materials.

26. First Aid Fire fighting arrangement in the style of placing suitable type of portable Fire Extinguishers. Fire Buckets etc. in all floors and vulnerable locations of the premises shall be made in accordance with I.S.2190-1992.

27. Fire License shall have to be obtained for proposed storing and processing with L.P.G and other highly combustible articles.

28. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.

29. Floor numbers and directional sign of escape route shall be displayed prominently.

30. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of /fire and /testing.

31. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times,

32. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.

33. Each year a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services.

34. N.B : Any deviation and changes the nature of use of the building in respect of the approved plane drawing, without obtaining prior permission from this office, this provisional N.O.C will be treated as cancelled.

3

2. 1. The whole construction of the proposed building shall be carried out as per approved

- plan drawings conforming the relevant building rules of local Municipal Body.
2. The floor area exceeds 750m² shall be suitable compartmented by separation wall up to ceiling level having at least two hours Fire resisting capacity.
 3. The interior finish decoration of the building shall be made low flame spread materials conforming I.S specifications,
 4. Provision of ventilation at the crown of the central core- duct of the building shall be provided.
 5. Arrangement shall have to be made for sealing all the vertical ducts by the materials of adequate Fire resisting capacity.
 6. The open space surrounding the building shall conform the relevant building rules as well as permit the accessibility and maneuverability of Fire appliance with turning facility.
 7. The approach roads shall be sufficiently strong to with stand the loan of Fire Engine weighting up to 20 M.T.
 8. The width and height of the access gates into the premises shall not be less than 4.5-5 M respecting abutting the road,
 9. The staircase of the building shall be enclosed type. Entire construction shall be made of bricks / R.C.C .type having Fire resisting capacity not less than 4 hours.
 10. The staircase of the building shall have permanent vents at the top and open able sashes at each floor level in the external wall of the building.
 11. All the staircase shall be extended up to terrace of the building and shall be negotiable to each other without entering into any room.
 12. Fire and smoke doors at the entrances of the Staircase enclosures as marked in the plan at each floor level shall be provided. The F.C.D. shall be of at least one hour Fire. Resisting wire glass window fitted with self- closing type open able in the direction of escape.
 13. Overhead reservoir of 5,000 lts/min. preferably from two different sources of water supply shall be provided. The water reservoir shall have overflow arrangement with the domestic water reservoir as well as to avoid stagnancy of water. The water reservoir shall be kept full at all time.
 14. The building shall be provided with down corner of 100mm internal diameter pipe line with provision of landing valves at the Staircase landings/half landings at the rate of one such riser for 1000 Sq m of floor area.
 15. Provision for Hose Reel in conjunction with down comer shall be made at each floor level conforming the relevant I.S. Specifications Provision for down comer shall be made at each floor level. Conforming the relevant I.S Specifications.
 16. One main fire pump and one standby pump, preferably diesel driven, of capacity minimum 1850 LPM and head of the pump will be such that 3.5 Kg/cm² pressure is available at the furthest/highest landing valve to be installed. Auto start facility should be incorporated in fire pump. Accordingly, Jokey pump of capacity 180LPM shall also be installed, conforming to the norms of National Building Code part-IV- fire and life safety.
 17. The Electrical installation including transformers. Switch Gears, Main & Meters etc. and

the distribution system of the premises shall be made satisfying the code of practice for Fire safety in general building as laid down in I.S. specification 1946-1982.

18. The vertical ducts shall be supply sealed at alternative floor level.

19. Arrangement shall have to be made to supply power with the help of a generator to operator at least the /fire Pump for deep Tube-well, Fire Alarm System, Fire Lift etc. and also for illuminating the Staircase, corridors etc. and other places of the building in case of normal power failure.

20. Manually operated Electrical Fire Alarm system with at least three numbers of break glass type call boxes fitted with Hooters along with public address system, talk back system at each floor connecting with audio- visual panel board shall be made in Control Room. The Control Room shall be located at the entrance of Ground Floor of the building, other requirements of the system shall be made conforming I.S. 2189-1988.

21. Public address system linked between all floors and Control Room shall have to be established.

22. The A.H.U shall be separated for each floor with the system Air Ducts for individual floors.

23. Arrangement shall be made for isolation the strategic locations by incorporating auto dampers in the Air Conditioning system.

24. The system of auto shut down of A.H.U shall be incorporated with the auto detection and alarm system.

25. The air handling units room shall not be used for storage of any combustible materials.

26. First Aid Fire fighting arrangement in the style of placing suitable type of portable Fire Extinguishers. Fire Buckets etc. in all floors and vulnerable locations of the premises shall be made in accordance with I.S.2190-1992.

27. Fire License shall have to be obtained for proposed storing and processing with L.P.G and other highly combustible articles.

28. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.

29. Floor numbers and directional sign of escape route shall be displayed prominently.

30. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of /fire and /testing.

31. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times,

32. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.

33. Each year a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services.

34. N.B : Any deviation and changes the nature of use of the building in respect of the approved plane drawing, without obtaining prior permission from this office, this provisional N.O.C will be treated as cancelled.

3

Divisional Fire Officer
West Bengal Fire & Emergency Services

Validity unknown
Digitally signed by NITAI
CHATTOPADHYAY
Date: 2019.03.19 17:28:21 IST