## **GOVERNMENT OF WEST BENGAL**

OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D, Mirza Ghalib Street, Kolkata – 700 016

Memo No.: WBFES/7883 /17/ Kol/RB/783/13 (783/13)

Date: ..1.7.1.0 / 17

From:

Divisional Fire Officer,

Fire Prevention Wing

West Bengal Fire & Emergency Services

To

Mr. Rajiv Bansal,

77 Chetla Road,

Kolkata - 700 027

Sub

Revised Fire Safety Recommendation for an existing B+G+M+VII storied under group

Residential Building at the premises no. - 77, Chetla Road, borough - IX, Ward No. - 82

under KMC, Kolkata - 700 027.

This is in reference to your letter No. - Nil dated 29/08/2017 regarding Revised Fire Safety measure for an existing B+G+M+VII storied under group Residential Building at the premises no. - 77, Chetla Road, borough – IX, Ward No. – 82 under KMC, Kolkata – 700 027.

The plan drawing submitted by you was scrutinized and marked as found necessary from fire safety point of view. In returning one set of plan, this office is issuing Revised Fire Safety Recommendation in favour of the aforesaid building subject to the compliance of the following fire safety measure which was recommended from this office earlier vide memo No. – WBFES / 3553/13/Kol-RB/783/13 (783/13) dated 26/07/2013 remain same & strictly to be followed with additional some condition.

## Additional condition:

1) Sprinkler System shall be provided in Basement, Ground Floor, & 1st (first) floor commercial areas and total Mezzanine Floor area of the building.

Enclo.:

1. One set of plan.

DIVISIONAL FIRE OFFICER
FIRE PREVENTION WING

WEST BENGAL FIRE & EMERGENCY SERVICES