

GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D, Mirza Galib Street, Kolkata – 700 016.

Memo. No. : WBFES/ 447/16 /Kol-RB/762/12 (762/12) Date :...19.01.16

From : The Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services.

To : The Authorised Signatory,
Sanon Sen Associates Pvt. Ltd.,
5, Russel Street, Ground Floor,
Kolkata-700 071.



Sub : Fire Safety Recommendation for Additional two floor over existing B+G+I Storied Commercial Building along with sanctioned B+G+XXI storied Residential Building at premises No.- 162, Arabinda Sarani, Kolkata-700 006, Ward No-11, Borough-11.


This is in reference to your letter No. Nil dated 08.10.2015 regarding Fire Safety Recommendation for Additional two floor over existing B+G+I Storied Commercial Building along with sanctioned B+G+XXI storied Residential Building at premises No.- 162, Arabinda Sarani, Kolkata-700 006, Ward No-11, Borough-11.

The revised plan submitted by you was scrutinized and marked as found necessary from fire safety point of view. In returning one set of plan, this office has approved **Revised Plan Drawing** in favour of the aforesaid building subject to the compliance of the fire safety measure as recommendation issued earlier vide this office memo no.- WBFES/2038/12/Kol-RB/762/12 (762/12) dt.-27/06/12 remain same & strictly to be followed.

Additional recommendation:- wet riser increased upto additional two floor & Automatic Sprinkler system shall be provided in all floor area.

Enclo. :

1. One set of plan.


19/1/16
Director
Fire Prevention Wing
WEST BENGAL FIRE & EMERGENCY SERVICES